

LONG-TERM MULTI(ANNUAL) MODULE



Long-term Modules

- Tools for integrated and modular energy management for distributed demand response provider and distribution grid operators
 - Annual and multiannual module calculates the available resources for flexibility, unit prices and the basis of the long term contract

LT module coordination

ID	Time (UTC)	Data exchange/ activity	D.5.3.1 (Annual and Multiannual) Nomenclature	module	Reads data	Puts data at disposal	Tri-gger
1	till December, before contract agreement	Calculation of flexibility needs, prices, penalty and quality of service by using "3Smart_LongTerm module_Flexibility calculation table.xls"	Result: DSO Flexibility table; Flexibility unit prices,penalty; Output for long term contract sheets	LT module	DSO (staff)	DSO (staff)	0
2	till December, before contract agreement	Importing results of "3Smart_LongTerm module_Flexibility calculation table.xls"	Result: DSO Flexibility table; Flexibility unit prices,penalty; Output for long term contract data base tables	LT module	DSO (LT)(script1)	DSO (staff)	0
3	After step 2	Building EMS Microgrid module is fetching data from LT database		Microgrid	Building	DSO (LT)	0
4	After step 3	Building calculate flexibility offer	Result: Building Flexibility database table, tbd by Microgrid database developer	Microgrid		Building	0

Long term module coordination 2

ID	Time (UTC)	Data exchange/ activity	D.5.3.1 (Annual and Multiannual) Nomenclature	module	Reads data	Puts data at disposal	Tri-gger
5	After step 4	DSO (LT) module is fetching data from Microgrid database		LT	DSO (LT) (script2)	Building	0
6	After step 5	Generating file from Building Flexibility table	Result: Building Flexibility table in CSV or Excel	LT	DSO (staff)	DSO (LT) (script3)	0
7	After step 6	Contract preparation by DSO, inserting Building Flexibility table into "3Smart_LongTerm module_Flexibility calculation table.xls"	Result: Output for long term contract sheet	LT		DSO (staff)	
8	After step 7	Acceptance/Rejection of Building offer	Result: Offer acceptance sheet (Yes/No)	LT		DSO (staff)	
9	After step 8	Importing Offer acceptance sheet of "3Smart_LongTerm module_Flexibility calculation table.xls"	Result: Offer acceptance database table (Yes/No)	LT	Building	DSO (LT) (script4)	

Long-term module coordination 3

Long Term Workflow

Grid

Building

Contract

Step	Activity	Link	Status
1	[DSO staff] is calculating flexibility needs, prices, penalty and quality of service by using "3Smart_LT module_v1.xlsm"	Template	?
2	[DSO staff] is importing the results of "3Smart_LT module_v1.xlsm"	Import DSO Flex Table	?
3	[Building EMS Microgrid module] is fetching data from LT database		?
4	[Building EMS Microgrid module] is calculating flexibility offer		?
5	[DSO LT module] is fetching data from Microgrid database	Building Flexibility	?
6	[DSO LT module] is generating file from Building Flexibility table	Building Flexibility	?
7	[DSO staff] is preparing contract in "3Smart_LT module_v1.xlsm"		?
8	[DSO staff] is importing the prepared contract from "3Smart_LT module_v1.xlsm"	Import Contract	?

Communication model-description

1_Calculation of flexibility needs, prices, penalty and QoS

DSO staff is opening the excel file “3Smart_LongTerm module Flexibility calculation table.xls” and is filling preliminary data required by DSO flexibility and price calculations. Based on the input the excel is calculating automatically the results situating on the following tabs: “DSO Flexibility table”, “Flexibility unit prices, penalty” and “Output for long term contract”.

2_Importing results of “3Smart_LongTerm module_Flexibility calculation table.xls”

DSO staff is logging into the Long term module web application and is executing the import script by clicking on the corresponding menu item. After selecting “3Smart_LongTerm module_Flexibility calculation table.xls” from the user’s pc, the script is moving the result sheets content into the LT database. The following database tables will be written:

- contract
- dso_flexibility_table
- flexibility_unit_prices_and_penalty

At the same time the building_flexibility_table entries for that contract are removed. For the first import of that excel there is no such data anyway but it may happen that a reimport is necessary which invalidates the eventual building flexibility data belonging to the previous import.

Whenever an import activity is performed, the Microgrid staff needs to be notified that building flexibility calculations have to be (re)executed.

Communication model-description

3_Building EMS Microgrid module is fetching data from LT database

The general 3Smart concept in data exchange is to use Pull method for data transfers between the different modules. For that reason Microgrid side needs to implement a communication script which is going to read the above mentioned LT database tables and copy data to its own local communication tables. As the script is to be used once a year per building but at an undefined time, it wouldn't make much sense to schedule it for automatic processing. Our recommendation is to execute that script manually by Microgrid staff after receiving a notification from DSO staff that new result data is available

4_Building calculates flexibility offer

Based on the DSO flexibility data and prices the Microgrid is calculating a flexibility offer and stores the result in a communication table (Building Flexibility table) which is yet to be defined. Microgrid staff is notifying DSO staff that new building flexibility data is available for reading.

5_DSO (LT) module is fetching data from Microgrid database

A py script is reading the building flexibility data from the Microgrid's communication table and copying it to the appropriate LT database table (building_flexibility_table). For the same reasons as mentioned in step 3 the DSO staff is going to execute that script manually by choosing the corresponding menu item instead of scheduling it for regular running. DSO staff will need to know that new data is available – by communication between DSO and Microgrid staff (step 4).

Communication model-description

6_Generating file from Building Flexibility table

DSO staff is exporting the content of the building_flexibility_table database table to a csv file on the local pc by executing a py script via the web application. That file will serve as an input for the Contract preparation activity performed by “3Smart_LongTerm module_Flexibility calculation table.xls”.

7_Contract preparation by DSO

DSO staff is copying the above csv content into the “3Smart_LongTerm module_Flexibility calculation table.xls” onto the “Building Flexibility table” sheet. Using that data the excel file is going to create the final result – the contract offer by filling automatically the “Output for long term contract” sheet.

8_Acceptance/Rejection of Building offer

DSO staff is accepting / rejecting the building offer by updating the “Offer acceptance” sheet in “3Smart_LongTerm module_Flexibility calculation table.xls”.

9_Importing Offer acceptance

DSO staff is executing a py script to import Offer acceptance information from “3Smart_LongTerm module_Flexibility calculation table.xls” to the LT database making it available for reading by other modules like Microgrid.

SHORT TERM DAY-AHEAD MODULE



Short-term Day-Ahead Module

- day – to – day operation module for determining building flexibility potential as the distribution network/system operator asset:
 - Interconnection with long term module and receiving flexibility requirements
 - Defined flexibility requirements in long term module are set as maximum value bound in short term DA module
 - AC OPF in Python (Gurobi solver) is run daily to define HOW MUCH (from 0 to max reserved capacity) of the reserved flexibility capacity will be activated the next day (bound by long term contact)

ST Day-Ahead Module Input

- From Grid.xlsx:
 - Grid information (grid topology, lines descriptions)
 - Active and reactive power profiles for every node defined for specific dates in year (3 characteristics profiles for every moth)
- From Long-term contract:
 - Building flexibility table

Module coordination

- Day before delivery of electricity
 - At **11.00 AM** (UTC) CROPEX publish (at 10:40 UTC) the Day-Ahead prices
 - „Retailer” gather the data, extend hourly prices to 15 min prices, convert prices to EUR/kWh and **store** into table „Retailer to building DA prices” in „Retailer” DB

Retailer database outlook

retailer on postgres@3s_grid

```
1 SELECT * FROM public.retailer_to_building_da_prices
2
```

Data Output	Explain	Messages	Notifications	Query History
id [PK] integer	retailer_id integer	profile character varying (2000)	profile_created_at timestamp without time zone	
1	7	{ "DA prices": [0.0437, 0.0437,...	2019-02-03 11:48:50.887972	

{ "DA prices": [0.0437, 0.0437, 0.0437, 0.0437, 0.04137, 0.04137, 0.04137, 0.04137, 0.04048, 0.04048, 0.04048, 0.04048, 0.03921, 0.03921, 0.03921, 0.03921, 0.03855, 0.03855, 0.03855, 0.03855, 0.04072, 0.04072, 0.04072, 0.04072, 0.04923, 0.04923, 0.04923, 0.04923, 0.07315, 0.07315, 0.07315, 0.07315, 0.07963, 0.07963, 0.07963, 0.07963, 0.08009, 0.08009, 0.08009, 0.08009, 0.07233, 0.07233, 0.07233, 0.067, 0.067, 0.067, 0.067, 0.06178, 0.06178, 0.06178, 0.06178, 0.06104, 0.06104, 0.06104, 0.06104, 0.06481, 0.06481, 0.06481, 0.06481, 0.06495, 0.06495, 0.06495, 0.06495, 0.06815, 0.06815, 0.06815, 0.06815, 0.10107, 0.10107, 0.10107, 0.10107, 0.07727, 0.07727, 0.07727, 0.07727, 0.07066, 0.07066, 0.07066, 0.06623, 0.06623, 0.06623, 0.06623, 0.0441, 0.0441, 0.0441, 0.0441, 0.0431, 0.0431, 0.0431, 0.0431, 0.0361, 0.0361, 0.0361, 0.0361], "Measuring unit": "EUR/kWh", "Valid from": "2019-02-03 23:00:00"}

```
1 SELECT * FROM public.retailer_to_building_da_prices
2
```

Data Output	Explain	Messages	Notifications	Query History
id [PK] integer	retailer_id integer	profile character varying (2000)	profile_created_at timestamp without time zone	
11	19	{ "DA prices": [0.04202, 0.042...	2019-01-07 17:30:05.478255	
12	20	{ "DA prices": [0.06251, 0.062...	2019-01-08 17:30:05.478251	
13	21	{ "DA prices": [0.05846, 0.058...	2019-01-09 17:30:05.478278	
14	22	{ "DA prices": [0.06166, 0.061...	2019-01-10 17:30:05.4782	
15	23	{ "DA prices": [0.0651, 0.0651...	2019-01-11 17:30:05.51782	
16	24	{ "DA prices": [0.06344, 0.063...	2019-01-12 17:30:05.51782	
17	25	{ "DA prices": [0.05306, 0.053...	2019-01-13 17:30:05.51782	
18	26	{ "DA prices": [0.06214, 0.062...	2019-01-14 17:30:05.51782	
19	27	{ "DA prices": [0.06669, 0.066...	2019-01-15 17:30:05.51782	
20	28	{ "DA prices": [0.08001, 0.080...	2019-01-16 17:30:05.51782	
21	29	{ "DA prices": [0.06015, 0.060...	2019-01-17 17:30:05.51782	
22	30	{ "DA prices": [0.065, 0.065, 0...	2019-01-18 17:30:05.51782	
23	31	{ "DA prices": [0.06669, 0.066...	2019-01-19 17:30:05.51782	
24	32	{ "DA prices": [0.059, 0.059, 0...	2019-01-20 17:30:05.51782	
25	33	{ "DA prices": [0.07148, 0.071...	2019-01-21 17:30:05.51782	
26	34	{ "DA prices": [0.06157, 0.061...	2019-01-22 17:30:05.51782	
27	35	{ "DA prices": [0.06473, 0.064...	2019-01-23 17:30:05.51782	
28	41	{ "DA prices": [0.06463, 0.064...	2019-01-24 16:09:49.365266	
29	42	{ "DA prices": [0.06463, 0.064...	2019-01-24 16:10:04.599151	
30	43	{ "DA prices": [0.06463, 0.064...	2019-01-24 17:44:04.28671	
31	44	{ "DA prices": [0.06463, 0.064...	2019-01-24 20:27:32.337022	
32	45	{ "DA prices": [0.06463, 0.064...	2019-01-24 20:33:02.049466	
33	46	{ "DA prices": [0.06463, 0.064...	2019-01-24 20:33:22.226096	
34	47	{ "DA prices": [0.06463, 0.064...	2019-01-25 20:34:29.984231	
35	48	{ "DA prices": [0.04464, 0.044...	2019-01-26 18:43:02.694897	
36	49	{ "DA prices": [0.04706, 0.047...	2019-01-27 19:15:46.874447	
37	50	{ "DA prices": [0.04976, 0.049...	2019-01-28 11:19:05.883031	
38	51	{ "DA prices": [0.04701, 0.047...	2019-01-29 19:11:24.47434	
39	52	{ "DA prices": [0.05322, 0.053...	2019-01-31 19:10:06.929731	
40	53	{ "DA prices": [0.05322, 0.053...	2019-02-01 10:28:52.450285	
41	54	{ "DA prices": [0.05016, 0.050...	2019-02-01 20:28:12.850834	
42	55	{ "DA prices": [0.04517, 0.045...	2019-02-02 22:01:37.274	
43	56	{ "DA prices": [0.0437, 0.0437...	2019-02-03 19:48:50.921561	

Retailer database outlook

```

retailer on postgres@3s_grid
1 SELECT * FROM public.retailer_to_building_da_prices
2


```

```

1 SELECT * FROM public.retailer_to_building_da_prices
2

```

{"DA price":
 0.04137,
 0.03921,
 0.04072,
 0.04923,
 0.07963,
 0.07233,
 0.06178,
 0.06481,
 0.06495,
 0.10107,
 0.07066,
 0.0441,
 0.0361,
 "from": "2



id	ir	price	timestamp
42	55	1	2019-02-02 22:01:37.274
43	56	1	2019-02-03 19:48:50.921561

Module coordination

- At **12.00 AM (UTC)** **the building reads** the DA price profile from „Retailer” DB table „Retailer to building DA prices” and runs MPC
 - At **13.00 AM (UTC)** **the building stores** the result „Declared DA profile” in communication table „building_to_dso_declared_da_profiles”
 - **the DSO reads** the profile and stores in its own communication table when AC OPF is started

Database outlook

dso on postgres@3s_grid

```
1 SELECT * FROM public.building_to_dso_declared_da_profiles
2
```

Data Output	Explain	Messages	Notifications	Query History
id [PK] integer	building_id integer	profile character varying (3000)	profile_created_at timestamp without time zone	
1	1	{'declared_da_profile': [51.6...	2019-02-04 13:30:19.713084	

{'declared_da_profile': [51.622, 53.787000000000006, 54.728, 58.132, 56.885000000000005, 56.237, 56.932, 56.959, 56.596000000000004, 56.772000000000006, 56.534, 56.007999999999996, 56.077, 56.191, 55.366, 53.486000000000004, 53.236999999999995, 52.446, 52.844, 53.023999999999994, 52.607, 50.203, 50.539999999999999, 51.85, 61.81, 53.9, 51.726, 51.859, 46.728, 49.26, 49.483, 42.628, 42.387999999999999, 41.428, 41.141, 40.943, 40.899, 41.342, 41.481, 41.604, 41.799, 41.871, 41.931999999999995, 41.828999999999999, 41.973, 41.746, 41.933, 42.297, 42.455, 42.479, 42.7, 42.794, 42.647999999999996, 42.94, 42.772000000000006, 42.714, 42.843, 42.786, 42.863, 42.915, 42.968, 43.074, 42.943, 42.913, 42.979, 43.038, 43.254000000000005, 44.061, 43.275999999999996, 54.825, 58.078, 78.765999999999999, 74.7, 67.782000000000001, 69.033999999999999, 64.38, 59.166, 59.703999999999999, 60.242, 61.916000000000004, 63.428, 64.764000000000001, 62.852, 64.454000000000001, 61.600999999999999, 62.694, 63.524, 62.726000000000006, 60.739999999999995, 58.613, 58.803, 63.007999999999996, 60.995, 63.929, 70.607, 65.636], 'measuring_unit': 'kWh', 'valid_from': '2018-02-04 23:00:00'}

dso on postgres@3s_grid

```
1 SELECT * FROM public.building_to_dso_declared_da_profiles
2
```

Data Output	Explain	Messages	Notifications	Query History
id [PK] integer	building_id integer	profile character varying (3000)	profile_created_at timestamp without time zone	
1	1	{'valid_from': '2018-12-13 0...	2018-12-11 23:44:47.509918	
2	2	{'valid_from': '2018-12-13 0...	2018-12-11 23:47:49.023675	
3	3	{'valid_from': '2018-12-13 0...	2018-12-11 23:50:06.826921	
4	4	{'valid_from': '2018-12-13 0...	2018-12-11 23:55:11.779649	
5	5	{'valid_from': '2018-12-13 0...	2018-12-11 23:55:22.83317	
6	6	{'valid_from': '2018-12-13 0...	2018-12-11 23:57:14.576792	
7	7	{'valid_from': '2018-12-13 0...	2018-12-12 00:00:57.386639	
8	8	{'valid_from': '2018-12-13 0...	2018-12-12 00:02:05.532131	
9	9	{'valid_from': '2018-12-13 0...	2018-12-12 00:02:43.999425	
10	10	{'valid_from': '2018-12-13 0...	2018-12-12 00:04:34.190611	
11	11	{'valid_from': '2018-12-14 0...	2018-12-12 07:58:38.982417	
12	12	{'valid_from': '2018-12-14 0...	2018-12-12 07:59:01.930168	
13	13	{'valid_from': '2018-12-14 0...	2018-12-12 07:59:53.970276	
14	14	{'valid_from': '2018-12-14 0...	2018-12-12 08:00:50.930219	
15	15	{'measuring_unit': 'kWh', 'v...	2018-12-12 08:49:54.18283	
16	16	{'measuring_unit': 'kWh', 'v...	2018-12-12 08:50:35.589541	
17	17	{'measuring_unit': 'kWh', 'v...	2018-12-12 08:52:49.261845	
18	18	{'measuring_unit': 'kWh', 'v...	2018-12-12 08:53:39.052097	
19	19	{'measuring_unit': 'kWh', 'v...	2018-12-12 08:54:01.973951	
20	20	{'measuring_unit': 'kWh', 'v...	2018-12-12 08:55:39.557233	
21	21	{'measuring_unit': 'kWh', 'v...	2018-12-12 08:55:59.647734	
22	22	{'measuring_unit': 'kWh', 'v...	2018-12-12 08:57:00.642555	
23	23	{'declared_da_profile': [['52...	2018-12-12 11:32:01.992102	
24	24	{'declared_da_profile': [['52...	2018-12-12 11:41:21.440806	
25	25	{'declared_da_profile': [['51...	2018-12-12 11:43:16.914286	
26	26	{'declared_da_profile': [['51...	2018-12-12 11:43:59.42221	
27	27	{'declared_da_profile': [['51...	2018-12-12 11:44:42.520898	
28	28	{'declared_da_profile': [['51...	2018-12-12 11:48:12.730764	
29	29	{'declared_da_profile': [['51...	2018-12-12 11:48:29.35575	
30	30	{'declared_da_profile': [['51...	2018-12-12 11:52:39.251857	
31	31	{'declared_da_profile': [['51...	2018-12-12 11:53:00.102413	
32	32	{'declared_da_profile': [['50...	2018-12-12 13:06:46.425783	
33	33	{'declared_da_profile': [['50...	2018-12-12 13:07:24.688093	
34	34	{'valid_from': '2018-12-14 0...	2018-12-12 13:18:53.815162	

AC OPF module


- Input:

- Grid data ✓
- Load profiles ✓
- Long-term – building flexibility profiles ✓
- Building „Declared DA profile” ✓

Defined for next day



- Output:

- Voltage and current state of network
- Building flexibility activation profile




AC OPF results

- Results visualised:
 - Voltage
 - Current
 - Active power
 - Reactive power




ST DA module results for 13/12/2018




Database schema

- Input tables for AC OPF
 - From excel, Neplan, building and long term module
- Output tables – AC OPF results
 - For plotly and building
- Rest of communication tables
- Archive of communication tables



EPHZHB building



3Smart First pilot study visit to the EPHZHB pilot: On-line demonstrations: 3Smart modules installed


Anita Martinčević, Nikola Hure, Danko Marušić, Hrvoje Novak

UNIZG FER

anita.martincevic@fer.hr, nikola.hure@fer.hr, danko.marusic@fer.hr, hrvoje.novak@fer.hr

3Smart pilot study visit to EPHZHB pilot No. 1 in Tomislavgrad

27 February 2019



Current EPHZHB modules status and upcoming plans


Current EPHZHB modules status

General prerequisites

1. Server connection (VPN SSTP)
2. Database connection (PgAdmin)
3. Python connection (PyCharm terminal, libraries etc.)
4. Historical data analysis

Current EPHZHB modules status

General prerequisites

1. **Server connection (VPN SSTP)** 
2. Database connection (PgAdmin)
3. Python connection (PyCharm terminal, libraries etc.)
4. Historical data analysis

Current EPHZHB modules status

General prerequisites

1. Server connection (VPN SSTP)
- 2. Database connection (PgAdmin) ✓**
3. Python connection (PyCharm terminal, libraries etc.)
4. Historical data analysis

Current EPHZHB modules status

General prerequisites

1. Server connection (VPN SFTP)
2. Database connection (PgAdmin)
3. Python connection (PyCharm terminal, libraries etc.)
4. Historical data analysis



Current EPHZHB modules status

General prerequisites

1. Server connection (VPN SFTP)
2. Database connection (PgAdmin)
3. Python connection (PyCharm terminal, libraries etc.)
4. **Historical data analysis**



Current EPHZHB modules status

ZONE LEVEL MODULES

- Z.PE.6 – historical data accumulation (Z.PE.5)
- Z.PE.7 – in online operation, 'local_switch' needs to be changed

HVAC LEVEL MODULES

- HVAC.PE.4 – data and Python coding ready, waiting for Linux machine setup to finalize
 - HVAC non-controllable consumption submodule – in online operation

MICROGRID LEVEL MODULES

- M.PE.3 – location of pyranometers will be changed, Linux machine setup needs to be finalized
- M.PE.4 – Waiting for Linux machine setup finalization and FCU electrical consumption calculation (Z.PE.1)
 - Microgrid non-controllable consumption submodule – waiting for FCU electrical consumption to be calculated (Z.PE.1)
- M.MPC.1 – requires solver to be installed, otherwise ready

Current EPHZHB modules status

ZONE LEVEL MODULES

- Z.PE.6 – historical data accumulation (Z.PE.5)
- Z.PE.7 – **in online operation**, 'local_switch' needs to be changed

HVAC LEVEL MODULES

- HVAC.PE.4 – data and Python coding ready, waiting for Linux machine setup to finalize
 - HVAC non-controllable consumption submodule – in online operation

MICROGRID LEVEL MODULES

- M.PE.3 – location of pyranometers will be changed, Linux machine setup needs to be finalized
- M.PE.4 – Waiting for Linux machine setup finalization and FCU electrical consumption calculation (Z.PE.1)
 - Microgrid non-controllable consumption submodule – waiting for FCU electrical consumption to be calculated (Z.PE.1)
- M.MPC.1 – requires solver to be installed, otherwise ready

Current EPHZHB modules status

ZONE LEVEL MODULES

❖ Z.PE.1

- Calorimeter temperature resolution set to 0.1 °C → done
- Experiments on individual* FCU required for identification of hydraulic model (*only on units with return medium sensor)
- Sensor calibration
- Identification of the hydraulic system model
- Selection of fan coil units to perform longer experiments required to identify thermodynamic fan coil unit model
- Performing experiments on few selected fan coil unit types
- Identification of thermodynamic system model
- Putting all identified models to database
- Putting online part of Z.PE.1 into operation

❖ Z.PE.5

❖ Z.MPC.1

❖ Z.I.1

Current EPHZHB modules status

ZONE LEVEL MODULES

- Z.PE.6 – historical data accumulation (Z.PE.5)
- Z.PE.7 – in online operation, 'local_switch' needs to be changed

HVAC LEVEL MODULES


- HVAC.PE.4 – data and Python coding ready, waiting for Linux machine setup to finalize
 - HVAC non-controllable consumption submodule – **in online operation**

MICROGRID LEVEL MODULES

- M.PE.3 – location of pyranometers will be changed, Linux machine setup needs to be finalized
- M.PE.4 – Waiting for Linux machine setup finalization and FCU electrical consumption calculation (Z.PE.1)
 - Microgrid non-controllable consumption submodule – waiting for FCU electrical consumption to be calculated (Z.PE.1)
- M.MPC.1 – requires solver to be installed, otherwise ready


Current EPHZHB modules status

AHU ground floor thermal energy consumption




Current EPHZHB modules status

AHU ground floor thermal power




Current EPHZHB modules status

AHU ground floor thermal power - median




Current EPHZHB modules status

AHU ground floor thermal power - median




Current EPHZHB modules status

AHU ground floor thermal power




Current EPHZHB modules status

AHU ground floor thermal power - median



Current EPHZHB modules status

AHU ground floor thermal power - median



HVAC MPC 2a


Heat pump and heating block

3smart control

HVAC MPC 1 – module operation

- Description: medium temperature optimisation → costs and comfort
- Module interaction on HVAC level:
 - 4.2.1. – Microgrid MPC module
 - 4.3.1. – P&E modules
 - 4.4.1. – Zone MPC module
- Execution frequency: 15 minutes
- <15 min. coordination between the microgrid, HVAC and zone MPC

HVAC MPC 1 – information flow




Parameters: \dashrightarrow

Signals: \longrightarrow

Prediction vector: $(x)_N = [x(0), x(1), \dots, x(N-1)]$

Index first element: #

HVAC MPC 1 – information flow




Parameters: \dashrightarrow

Signals: \longrightarrow


Prediction vector: $(x)_N = [x(0), x(1), \dots, x(N - 1)]$

Index first element: #

Medium conditioning functional scheme




Medium conditioning functional scheme




Medium conditioning functional scheme

Design constraint:
3Smart should not interfere with the low-level control loops!



Optimal control problem (1/3)

- Objective: minimise consumed (electrical) **energy cost** (volatility)
- DOF: Heat tank temperature
- Manipulated values:
 - Heating block power
 - Heat pump operation



Optimal control problem (2/3)

- Constraints:

- Delivered energy to the zones $(E_{t,z})_N$

- HVAC el. consumption

- Heating block power: $0 \text{ kW} \leq P_{\text{el,hb}} \leq 88 \text{ kW}$


- Heat pump (heating) power:

$$0 \text{ kW} \leq P_{\text{t,hp}} \leq 74.7 \text{ kW}$$

- Heat pump supply temperature


Optimal control problem (3/3)

- Heat pump supply temperature and environment temperature



Optimal control problem (3/3)

- Heat pump supply temperature, environment temperature




Required module inputs

Input	Notation	Unit	Source
Required thermal energy inputs prediction	$(E_{t,z})_N$	[kWh]	Z.MPC.1 module
Zone temperatures predictions	$(T_z)_N$	[°C]	
Environment temperature prediction	$(T_{env})_N$	[°C]	Weather service/forecast
Noncontrollable thermal loads Heating energy price	$(E_{t,nc})_N$	[€/kWh]	HVAC.PE.4 module
Electric energy consumption cost and constraints	$J_M((E_e)_N)$	[kWh]	M.MPC.1 module
COP model parameters	N/A	N/A	HVAC.PE.1 module
Flow shares model	N/A	N/A	HVAC.PE.2 module
Parameters of heat./cool. elements models	N/A	N/A	Z.PE.1 module


HVAC related measurements...

Supply/return temperature heat pump




HVAC related measurements...


Supply/return temperature heat pump




HVAC related measurements...





HVAC related measurements...




HVAC related measurements...




HVAC related measurements...




HVAC related measurements...




HVAC related measurements...




HVAC related measurements...



HVAC related measurements...



HVAC related measurements...



HVAC MPC 1 tables

hvac_mpc2_outputs
hvac_mpc2_outputs_history



Implementation timetable

- Technical requirements:
 - linear solver installed and required python packages
 - EMS references to BMS connection

Current EPHZHB modules status

ZONE LEVEL MODULES

- Z.PE.6 – historical data accumulation (Z.PE.5)
- Z.PE.7 – in online operation, 'local_switch' needs to be changed

HVAC LEVEL MODULES

- HVAC.PE.4 – data and Python coding ready, waiting for Linux machine setup to finalize
 - HVAC non-controllable consumption submodule – in online operation

MICROGRID LEVEL MODULES

- M.PE.3 – location of pyranometers will be changed, Linux machine setup needs to be finalized
- M.PE.4 – Waiting for Linux machine setup finalization and FCU electrical consumption calculation (Z.PE.1)
 - Microgrid non-controllable consumption submodule – waiting for FCU electrical consumption to be calculated (Z.PE.1)
- M.MPC.1 – requires solver to be installed, otherwise ready (short-term)

Additional prerequisites for Linux server environment

- Basic prerequisites published in WP7:

[3Smart_modules_installation_and_monitoring_v0.5_UNIZGFER.docx](#)

- Some Python packages needed:

- ipython
- json, simplejson
- apscheduler
- numpy, scipy, pandas, sklearn
- pysolar, pytz, threading
- psycopg2/pymssql (depending on installed DB)
- ...

- Full list and instructions to be published by tomorrow
- Either pre-install packages or give developers rights to do that
- If Linux is installed on a VM, 8GB RAM and 4-8 CPU cores minimum; DB must be directly accessible from VM

Grid-side modules installed on Bosnia and Herzegovina pilot

Tomislav Capuder/ Paula Mamić / Mirna Gržanić

University of Zagreb Faculty of Electrical Engineering and Computing

Tomislav.capuder@fer.hr; paula.mamic@fer.hr; mirna.grzanic@fer.hr

3Smart – First BA pilot visit

26.02-27.02.2019.



UNIVERSITY OF ZAGREB
FACULTY OF
ELECTRICAL
ENGINEERING
AND COMPUTING



Interreg



EUROPEAN UNION

Danube Transnational Programme

3Smart

Project co-funded by the European Union

Content

- BA pilot grid overview
- Long-term module
 - LT Multiannual & Annual contract
- Short-term module
 - ST Day-ahead modul

LONG TERM (MULTI)ANNUAL MODULE




Long-term (Multi)Annual Module

- Tools for integrated and modular energy management for distributed demand response provider and distribution grid operators
 - Annual and multiannual module calculates the available resources for flexibility, unit prices and the basis of the long term contract

LT Annual module

Month	Type of day	flexibility requirement [kW]	Time interval (Start)	Time interval length	flexibility requirement[kW]	Pcs of type of days	Time interval (End)
2017-01	WEEKDAYS	-11.38	11:30	3.50	-39.82	22	15:00
2017-02	WEEKDAYS	-11.38	11:30	3.50	-39.82	20	15:00
2017-06	WEEKDAYS	-23.22	10:30	0.50	-11.61	22	11:00
2017-06	WEEKDAYS	-23.22	11:30	0.25	-5.81	22	11:45
2017-06	WEEKDAYS	-73.63	13:00	0.50	-36.81	22	13:30
2017-06	WEEKDAYS	-73.63	14:30	0.50	-36.81	22	15:00
2017-07	WEEKDAYS	-23.22	10:30	0.50	-11.61	21	11:00
2017-07	WEEKDAYS	-23.22	11:30	0.25	-5.81	21	11:45
2017-07	WEEKDAYS	-73.63	13:00	0.50	-36.81	21	13:30
2017-07	WEEKDAYS	-73.63	14:30	0.50	-36.81	21	15:00
2017-08	WEEKDAYS	-23.22	10:30	0.50	-11.61	23	11:00
2017-08	WEEKDAYS	-23.22	11:30	0.25	-5.81	23	11:45
2017-08	WEEKDAYS	-73.63	13:00	0.50	-36.81	23	13:30
2017-08	WEEKDAYS	-73.63	14:30	0.50	-36.81	23	15:00
2017-12	WEEKDAYS	-11.38	11:30	3.50	-39.82	21	15:00

LT Annual module



LT Multiannual module

Service name	Flexibility service
1) Contract valid from	1/1/2017
2) Contract valid until	12/31/2017
3) Est. no. of activations during period	327
4) Maximum Size of service in power (kW)	9.60
5) Max. duration of service per activation (h)	3.5
6) On - Trigger	Signal from the DSO or according to calculator
7) Off - Trigger	Maximum: see "Max.duration of activation" from "on"-signal, or by from the DSO
8) Maximum allowed activation time	15 min (but it depends of the cap Customer process technology)

9) Quality of Service	- Deviation in max. duration: +/- 15 min. - Deviation from, On - Trigger: +/- 15 min. Deviation in size of service: Max. - 10% deviation - Acceptable no. of unsuccessful activations: x
10) Unit price of Reservation (EUR/kWh)	43.54
11) Unit price of Activation (EUR/kWh)	0.38
12) Reservation fee for the contractual period	418.01
13) Activation fee for the whole contractual period	1,214.11
14) Average activation price/activation	3.71
15) Pricing	1,632.13
16) Penalty if failed supply	121.41 3 times of failed delivery → termination of the contract

SHORT TERM DAY AHEAD MODULES







Short term Day-Ahead module


- day – to – day operation module for determining building flexibility potential as the distribution network/system operator asset:
 - Interconnection with long term module and receiving flexibility requirements
 - Defined flexibility requirements in long term module are set as maximum value bound in short term DA module
 - AC OPF in Python (Gurobi solver) is run daily to define HOW MUCH (from 0 to max reserved capacity) of the reserved flexibility capacity will be activated the next day (bound by long term contact)

The results for long term module (1)

- <https://plot.ly/~3SMART/2/my-graph/#/>



The results for long term module (1)





Project Deliverable Report

Smart Building – Smart Grid – Smart City

<http://www.interreg-danube.eu/3smart>

DELIVERABLE D6.3.1

Transnational training materials – Pilot study visits to Hungary – Pilot study visit No. 1

Project Acronym	3Smart
Grant Agreement No.	DTP1-502-3.2-3Smart
Funding Scheme	Interreg Danube Transnational Programme
Project Start Date	1 January 2017
Project Duration	36 months
Work Package	6
Task	6.3
Date of delivery	Contractual: 31 December 2019 Actual: 23 December 2019
Code name	Version: 2.0 Final <input checked="" type="checkbox"/> Final draft <input type="checkbox"/> Draft <input type="checkbox"/>
Type of deliverable	Report
Security	Public
Deliverable participants	UNIZGFER, UNIDEBTTK, EON, UNIBGFME
Authors (Partners)	Mario Vašak, Tomislav Capuder, Vinko Lešić, Anita Martinčević, Hrvoje Novak, Danko Marušić, Nikola Hure, Paula Mamić (UNIZGFER), Arpad Racz, Andras Mucsi (UNIDEBTTK), Gabor Peter, Kata Santa (EON), Vladimir Jovanović (UNIBGFME)
Contact person	Arpad Racz (UNIZGFER)
Abstract (for dissemination)	This document contains the minutes of the first study visit to the Hungarian pilot in 3Smart. It consists of a pilot building – EON headquarter building in Debrecen – and the pilot electricity distribution grid around the building. On the pilot study visits the pilot leaders and hosts together with developers for different modules on the pilot site have performed demonstration to the consortium of functioning of different installations performed on the pilot and of the installed 3Smart modules.
Keyword List	building-side energy management system, grid-side management, pilot installations, 3Smart IT environment, 3Smart database



Revision history

Revision	Date	Description	Author (Organization)
v1.0	15 February 2019	Entered the minutes from the first Hungarian pilot study visit in the deliverable form	Mario Vašak (UNIZGFER)
v2.0	23 December 2019	Prepared the minutes in publishable form	Mario Vašak (UNIZGFER)



Table of Contents

Executive summary	1
1. Minutes from the first pilot study visit to the 3Smart pilot in Hungary.....	2



Executive summary

The 3Smart project deals with transnational development of integrated energy management of buildings and energy distribution grids in real time. To substantiate knowledge transfer between partners, to synchronize developments and demonstrate the installation procedure to developers, pilots leaders and pilots hosts, a series of transnational trainings is organized, first for getting acquainted with the software modules for energy management, and then for getting acquainted with performed pilot installations and modules operation on the pilot site.

This deliverable provides minutes and materials from the pilot study visits to the 3Smart pilot in Hungary that consists of EON building in Debrecen and of the electricity distribution grid around this building. The visits were split in two parts for each pilot site – this first part of the deliverable for the Hungarian pilot site concerns the first pilot study visit.



1. Minutes from the first pilot study visit to the 3Smart pilot in Hungary

Time: February 5-6, 2019

Venue: EON building, Kossuth utca 41, Debrecen, Hungary

February 5, 2019 (Tuesday)

Time	Place	Event
09:00-11:00	Lecture room, ground floor	Technical session (TS) 1: Presentation of the performed installations and realized IT infrastructure
11:00-11:15	In front of the room	Coffee break
11:15-13:00	Lecture room/ EON building	TS2: EON building visit
13:00-14:00	Cafeteria	Lunch
14:00-16:00	Lecture room/ EON building	TS3: On-line demonstration of basic IT infrastructure performance with the installed equipment
16:00-16:15	In front of the room	Coffee break
16:15-18:00	Lecture room, ground floor	TS4: 3Smart modules organization on the sides of EON building and the grid
20:00-22:00	Valentino Ristorante	Working dinner

February 6, 2019 (Wednesday)

Time	Place	Event
09:00-11:00	Lecture room, ground floor	TS5: On-line demonstrations: Zone-level modules EON, Central-HVAC-level modules EON
11:00-11:15	In front of the room	Coffee break
11:15-13:00	Lecture room/ EON building	TS6: On-line demonstrations: Microgrid-level EON
13:00-14:00	Cafeteria	Lunch
14:00-16:00	Lecture room/ EON building	TS7: On-line demonstrations: Short-term modules grid, Long-term modules grid
16:00-16:15	In front of the room	Coffee break
16:15-17:00	Lecture room, ground floor	TS8: Discussion, planning

Day 1:

Technical session 1: Presentation of the performed installations and realized IT infrastructure

Presentation of the performed installations on the building side was performed by Arpad Racz (UNIDEBTTK) and of the performed installations on the grid side by Gabor Peter (EON).

Details are provided in the appended presentation (Annex 1).



Technical session 2: Visit to EON building installations

Pilot visit encompassed all major points of installation in the building: the rooms where return medium sensors and integration through wireless transmitters were shown, the heating substation of one of the buildings, the heating center with central heat exchanger connected to the district heating system supply, the archives area where electric heaters actuators were integrated, and the roof with photovoltaic installation and the weather station.

Technical session 3: On-line demonstration of basic IT infrastructure performance with the installed equipment:

- communication with field devices in the building (sensors, actuating units) and the 3Smart database
- realization of on-off switches for 3Smart functionality on central HVAC level and microgrid level
- securing comfort for end-users in case of EMS failure
- building-grid communication and communication with the weather forecast service

Data communication from the 3Smart database to the SCADA database and back was on-line demonstrated. Accessibility for different actions and monitoring via SCADA was shown, and also the possibilities of the analytics tool Qlik which provides different data visualization possibilities.

3Smart on-off switches were explained, and also the roll-back procedure in case of failure in the modules execution or lost connection to the server with the database. More technical details are provided in Annex 2.

Grid-building communication tables were discussed in more details, including the time resolution of day-ahead and intra-day prices. Although day-ahead prices change in hourly intervals, the prices will be presented in the database as 15-min values by repeating each hourly value 4 times in 4 consecutive 15-minute intervals of a particular hour.

Technical session 4: 3Smart modules organization on the sides of EON building and the grid

Organization and timing of execution of grid-side modules was presented by Paula Mamić (for the short-term modules) and Gabor Peter (for the long-term modules). The presentations related to this part are provided as Annex 3 and Annex 4.

Arpad Racz gave an overview of the building-side modules, and Mario Vašak explained the envisioned interaction between different building-side modules. The related presentation is given in Annex 5.



Day 2:

Technical session 5: On-line demonstrations: Zone-level modules EON, Central-HVAC-level modules EON

Operation of Z.PE.1 (fan coils identification), Z.PE.4 and Z.PE.5 modules was presented by Anita Martinčević. Z.PE.1 is on-line and running for buildings B+C and E, Z.PE.4 performed off-line to get the parameters for rooms with electric heaters in the archives. More details are given in Annex 6.

Operation of Z.PE.8 (fan coils heat consumption), Z.PE.9 (rooms temperature prediction) and HVAC.PE.4 (non-controllable heat consumption) was elaborated by Hrvoje Novak. Initial data checks revealed some problematic input data on the side of temperature measurements (outliers) for Z.PE.9 and on the side of calorimeters measurements for HVAC.PE.4. For calorimeter measurements a formula was shown to calculate the power consumption.

Also, formula for computation of the non-controllable heat consumption in HVAC.PE.4 was agreed, but through later discussion it was decided to hold on to the final decision how non-controllable consumption is to be formulated (related to the discussion of return pipe losses from below).

HVAC.PE.1 and HVAC.PE.2 modules were presented by Vladimir Jovanović. The presentation provided by Vladimir is given in Annex 7.

Nikola Hure has presented the functioning of HVAC.MPC.1 module which runs on the actual 3Smart database data in combination with generic profiles created by Nikola for testing, for those predictions that are still not operable (see Annex 6). Nikola has shown the module planning in terms of the supply temperature profile it predicts for the optimal operation of the central HVAC system.

Technical session 6: On-line demonstrations: Microgrid-level EON

On the microgrid level Hrvoje has shown the performance of M.PE.3 (prediction of maximum possible PV production) and M.PE.4 (prediction of electrical non-controllable loads).

M.PE.3 is installed and put in online operation. Hrvoje has strongly emphasized the need to have checked data in the database in order to facilitate the prediction modules operation both in tuning the prediction models and in providing predictions.

For M.PE.4 the formula for non-controllable electricity consumption was discussed and finally accepted.

Danko Marušić has presented the functioning of microgrid MPC module. It was demonstrated what behaviour from the building can be induced by coordination between different optimization levels.

Presentation of UNIZGFER modules on the microgrid level is provided as Annex 8.

Arpad and Andras have presented the current status and operation of building-side modules for which UNIDEBTTK is responsible. Modules M.I.4 (electric heaters control) and M.I.5 (PV inverter control) were discussed. The presentations for M.I.4 and M.I.5 are provided as Annex 9.



Technical session 7: On-line demonstrations: Short-term modules grid, Long-term modules grid

Gabor from EON presented the workflow for executing the long-term module, with all necessary steps explained in detail. The shown presentation is given as Annex 10.

Short-term modules operation was demonstrated by Paula. For day-ahead module different unclear issues were resolved such that EON development team can continue with finishing the database part for the short-term modules.

The intra-day module is discussed in more detail. The shown presentation is part of Annex 3.

Technical session 8: Discussion, next steps at the pilot site, schedule updating for installations, questions. Possibility for preparing the next pilot study visits, technical questions. Grid-side developers open hour.

The last session was used for various face-to-face interactions between pilot leaders / hosts and the developers.

List of annexes

Annex 1: Presentations of performed mechanical, electrical and IT installations

Annex 2: Presentation of on-line operation of the pilot IT infrastructure

Annex 3: Presentation of short-term grid-side modules operation

Annex 4: Presentation of long-term grid-side modules operation

Annex 5: Modules organization on the building side

Annex 6: Presentation of UNIZGFER building-side modules installation and operation on the zone and central HVAC levels

Annex 7: Presentation of UNIBGFME modules installation

Annex 8: Presentation of UNIZGFER building-side modules installation and operation on the microgrid level

Annex 9: Presentation of UNIDEBTTK modules installation and operation

Annex 10: Presentation of EON grid-side modules installation and operation

Performed installations and realized IT infrastructure

Árpád Rácz, Zoltán Juhász, Katalin Décseiné Giczi,
Gábor Péter

University of Debrecen, IT Services, EON Tiszántúli Áramhálózati Zrt.


racz.arpad@science.unideb.hu

First pilot study visit to the Hungarian pilot

February 5-6, 2019.



System overview - Plan



Communication network

- Planning aspects:
 - As uniform as possible
 - Future-proof
 - Usage of current ModBus cabling
 - EON IT restrictions



Communication Network



Communication Network - Planning phase 2017 Q2-Q3

- Clarification of network requirements
- Survey of the existing structured cabling
- E.ON Corporate Network was not allowed to be used
- Wiring closets and legacy racks can be used
- WLAN access-points should be placed to corridors (instead of offices)
- WLAN coverage areas
- Min -64dBm RSSI value in the designated offices
- WLAN site surveys
- Endpoints positions on floor plans (with basement CIAT and power meter)
- Missing Fibre-optical cabling between building B and D



Communication network - Building phase 2017 Q4

- Building new structured cable system:
 - 114 endpoints (55 double)
 - 7600m Cat6 UTP cable
 - 7 pieces Cat6 UTP 24p patchpanel
 - 100m 8x OM3 fibre-optic cable between building B and D
- Mounting and installing network devices:
 - 1 pcs UniFi Security Gateway 4P
 - 7 pcs UniFi Switch
 - 34 pcs UniFi AP-AC-Mesh
 - 7 pcs UniFi AP-AC-Lite



Communication Network - Selecting the network products

- Deciding factors:
 - cost effective and simple network management (Configuration, monitoring, SW upgrade, etc.)
 - All network devices from one vendor, one product line, if possible
- Switches:
 - Centralized management and statistics, SNMP,
 - 10/100/1000 Mbps RJ45 Ethernet Ports, SFP slots,
 - PoE (IEEE 802.3af/at), RSTP, VLAN, Port-mirroring, storm control, port aggregation
- Access-points:
 - Centralized management and statistics, multi SSID, guest WLAN
 - Wall or ceiling mounted, PoE powered, IEEE 802.11ac,
- Gateway
 - Centralized management and statistics, interVLAN-routing, dynamic routing
 - Site-to-Site and Site-to-Client(RAS) VPN
 - high packet forwarding and Firewall performance, SFP slot
 - Simple management of guest access
- IDS/ IPS function if possible




Network services


- Wireless access (multiple SSID)
 - 3SMART temperature sensors
 - 3SMART-service direct project participants
 - 3SMART-guest guests (Internet access only)
- Wired connectivity:
 - 3SMART server
 - Power meters
 - NAS-backup
- Site-to-Site VPN – University of Debrecen, Nextent and cloud server
- RAS VPN: L2TP/IPSec and SSTP VPN – built-in Windows client
- Firewall filter rules: WAN, LAN, Guest, E.ON Corporate Network
- Network Management: Unifi web surface, run on Unifi Cloud Key
- 10 /10 Mbps fibre-optic Internet connection with fix IP-subnet (/29)



3SMART Debrecen L2 network topology



3SMART Debrecen communication network




o



Network mgmt - Unifi Controller - Dashboard


Unifi CURRENT SITE hu-debr-koss

Everything is **great!**



Gatewa4P

Internet Connection Upload Theoretical Capacity Throughput



Routing Utilization




VPNs

NAME	STATUS	TUNNELS	AVG. TX DATA	AVG. RX DATA
RAS-VPN	●	0	0 B	0 B



























Network mgmt - Unifi Controller - Maps








































Network mgmt - Unifi Controller - Devices

ALL (48) GATEWAY/SWITCHES (8) APS (40) Search or select tag

DEVICE NAME	IP ADDRESS	STATUS	MODEL	VERSION ↓	DOWN	UP	ACTIONS ↔
 Gateway4P	192.168.3.1	CONNECTED	UniFi Security Gateway 4P	4.4.36.5146617	676 GB	40.3 GB	 LOCATE  RESTART
 A-1EM-folyoso	192.168.3.61	CONNECTED	UniFi Switch 16 POE-150W	4.0.15.9872	0.98 GB	1.33 GB	 LOCATE  RESTART
 E-FSZ-server	192.168.3.21	CONNECTED	UniFi Switch 16 POE-150W	4.0.15.9872	212 GB	112 GB	 LOCATE  RESTART
 D-2EM-router1	192.168.3.25	CONNECTED	UniFi Switch 8 POE-150W	4.0.15.9872	25.7 GB	3.16 GB	 LOCATE  RESTART
 E-3EM-folyoso	192.168.3.22	CONNECTED	UniFi Switch 8 POE-60W	4.0.15.9872	918 MB	1.74 GB	 LOCATE  RESTART
 D-2EM-router2	192.168.3.19	CONNECTED	UniFi Switch 24 POE-250W	4.0.15.9872	2.48 GB	4.99 GB	 LOCATE  RESTART
 B-3EM-folyoso	192.168.3.20	CONNECTED	UniFi Switch 8 POE-150W	4.0.15.9872	1.03 GB	1.94 GB	 LOCATE  RESTART
 B-1EM-folyoso	192.168.3.26	CONNECTED	UniFi Switch 8 POE-150W	4.0.15.9872	895 MB	1.82 GB	 LOCATE  RESTART

Showing 1-8 of 8 records. Items per page:

Network mgmt - Unifi Controller - Clients

NAME	IP ADDRESS	WLAN	AP/PORT	CHANNEL	PHY MODE	SIGNAL	ACTIVITY ↔	ACTIVITY DOWN ↓	ACTIVITY UP	UPTIME
 TRAFO-WLAN-bridge	192.168.0.57	3SMART-wired	D-ALA-D01	1	11ng (2.4 GHz)	74% (-61 dBm)		1.04 MB	1.57 MB	10d 1h 4...
 D-tető-inv	192.168.2.22	3SMART	E-4EM-E207	11	11ng (2.4 GHz)	99% (-47 dBm)		848 KB	3.98 MB	9h 37m 2...
 B-6EM-inv	192.168.2.21	3SMART	B-6EM-B603	11	11ng (2.4 GHz)	99% (-50 dBm)		767 KB	1.06 MB	9h 38m 5...
 ESP_24A9BD	192.168.2.97	3SMART	C-3EM-D33	6	11ng (2.4 GHz) 	30% (-79 dBm)		183 KB	4.88 MB	10d 47m
 ESP_24A9CA	192.168.2.56	3SMART	A-1EM-A19	1	11ng (2.4 GHz)	37% (-76 dBm)		181 KB	328 KB	5d 7h 59r
 ESP_24AA40	192.168.2.140	3SMART	A-FSZ-NAGYTARCYALO	6	11ng (2.4 GHz) 	64% (-65 dBm)		181 KB	4.62 MB	5d 8h 42s
 ESP_24AAACE	192.168.2.29	3SMART	D-1EM-D25	6	11ng (2.4 GHz) 	77% (-60 dBm)		180 KB	4.59 MB	10d 26m
 ESP_24A9FA	192.168.2.100	3SMART	E-2EM-KDSZ	1	11ng (2.4 GHz) 	62% (-66 dBm)		179 KB	4.82 MB	5d 11h 54
 ESP_305EA9	192.168.2.155	3SMART	A-FSZ-NAGYTARCYALO	6	11ng (2.4 GHz) 	87% (-56 dBm)		179 KB	4.51 MB	10d 1h 42
 ESP_24A9E7	192.168.2.69	3SMART	E-1EM-E014	6	11ng (2.4 GHz) 	47% (-72 dBm)		179 KB	4.87 MB	7d 6h 55r
 ESP_24A9C9	192.168.2.106	3SMART	E-2EM-KDSZ	1	11ng (2.4 GHz) 	59% (-67 dBm)		179 KB	4.81 MB	5d 11h 54
 ESP_24AABF	192.168.2.40	3SMART	D-1EM-D23	11	11ng (2.4 GHz) 	94% (-53 dBm)		179 KB	5.07 MB	7d 3h 51r
 ESP_24AA79	192.168.2.129	3SMART	D-FSZ-D19	6	11ng (2.4 GHz) 	72% (-62 dBm)		179 KB	4.45 MB	7d 3h 40r
 ESP_24AA3F	192.168.2.152	3SMART	C-1EM-D21	6	11ng (2.4 GHz)	57% (-68 dBm)		179 KB	4.42 MB	6d 12h 21

Building energy management hardware



Building energy management hardware

- Planning aspects:
 - Maximize controllable load
 - Limited zone-level functionality



Installed equipment

- 114 pcs room temperature sensors in the pilot building
- 141 pcs fan coil outlet water temperature sensors in the pilot building
- 83 pcs 270 Wp solar panels on the roof of B and D building
- 2 pcs solar inverter
- 6 pcs electrical heating control units
- 4 pcs three-way valve control units
- 4 pcs calorimeters for main supply
- 4 pcs temperature measurement sensors for buffer tanks
- 11 pcs electrical meters for large consumers or consumer groups
- 1 pcs meteorological station on the roof of building B
- 1 pcs server in the pilot building
- 2 smart meter for middle voltage measurement in the pilot grid area
- 1 smart meter for low voltage measurement in the middle per low voltage transformer station (main supply of the building)



Installed control functions, abilities

- Electrical heaters – controllable temperature, electrical consumption
- Three-way valve units – controllable temperature of the forward heating/cooling medium
- CIAT water chillers – controllable temperature setpoint of the forward water, electrical consumption
- Solar inverters – controllable power output in percentages, electrical consumption




Room installation (Zone level)

- Communication:
 - UDP packets (push with confirmation) via dedicated WiFi network
 - Internal clock synchronized in every hour




Room installation (Zone level)

- Measured:
 - room temperature
 - return medium temperature
- Sensor:
 - MCP9700 analog temperature sensor



Heat centers installation (HVAC level)

- DIRIS A40 electricity meter
- QALCOSONIC HEAT 2 calorimeter
- Lumel RE72 controller for the mixing valve



Heat centers installation (HVAC level)



Heat centers installation (HVAC level)



PV system (Microgrid level)


- 22.41 kWp photovoltaic plant
 - 83 PV panels (Solvis SV60-270)
 - 2 smart-grid-ready inverters (Fronius Symo 10.0-3-M with DataManager Card)



PV system (Microgrid level)



PV system (Microgrid level)



Electric heaters installation (Microgrid level)

- Components of the system:
 - 6 central control units (custom made)
 - 6 room temperature controls (custom made)
 - 1 electricity meter (Diris A40)
- Network connection: WiFi 2.4 GHz (IEEE 802.11 b/g/n)
- Communication protocol: custom over UDP (with message acknowledgment)



Electric heaters installation (Microgrid level)



Electric meters installation (Microgrid level)

- Each one has Modbus RS485 communication module
- One of them has an Ethernet communication module



Location	Measured value
Heat center A	Water chiller (CIAT) A consumption
Heat center A	Fan coils' consumption for heat centre A
Heat center B+C	Water chiller (CIAT) B+C consumption
Heat center B+C	Fan coils' consumption for heat centre B+C
Heat center D	Water chiller (CIAT) D consumption
Heat center D	Fan coils' consumption for heat centre D
Basement of building B	Water chiller (CIAT) E consumption
Heat center E	Fan coils' consumption for heat centre E
Basement of building D	Electric heaters at basement D
Basement of building B	Building E consumption
Transformer station next to the building	Overall building consumption


Weather station installation

- The weather station consists of the following components:
 - RK900-01 Automatic Weather Station
 - RK110-02 Wind Direction Sensor
 - RK100-02 Wind Speed Sensor
 - RK330-01 Ambient Temperature Humidity & Pressure Sensor
 - RK200-04 Solar Radiation Sensor (2 pcs)
 - RK95-03 Solar Power Supply System
 - TAB 50P battery



Communication: ModBus


BEMS software




BEMS software

List: Állapotok - Hőközpontok - E.ON 3Smart


[B központ pillanatnyi állapota]




[C központ pillanatnyi állapota]



[D központ pillanatnyi állapota]



BEMS software



BEMS software

localhost:4848/sense/app/C%3A%5CUsers%5Cjskis%5CDocuments%5CQlik%5CSense%5CApps%5Ceon3smart.qvf/sheet/7689a4ec-a56f-49bf-b7b9-c8a95...

Login Bitfinex News - Bitcoin News Kraken CryptoCompare Translate Bitbucket Scaleway termék Informatika nyelvt sl Waze Duolingo Markdown További könyvtárak

Save eon3smart Edit Analysis #2

No selections applied

Analysis #2

Location Name

- A.1 Iroda
- A.2 Iroda
- A.101 Iroda
- A.102 Iroda
- A.103 Iroda
- A.104 Előtér-Iroda
- A.105 Iroda
- A.106 Iroda
- A.201 Iroda

Average Energy Consumption by Cooled-down Degrees

10/1/2017

Measure Timestamp

Distribution of Hourly Average Room Temperature per Room

Average Room Temperature

Location Name

Measure Quantity...

- HS1
- HS2
- HS3
- HS4
- HS5
- ZH1
- ZH2
- ZI1
- ZI2

Distribution of Measure Values (Select one of the Measure Quantities)

Frequency

Measure Amount

Total Consumption of Heat Energy per Location

D.P20 Gépház	C.P10 Klíma gépház	B87 Műhely-Raktár	E.P29 Klíma gépház
--------------	--------------------	-------------------	--------------------



3SMART switch OFF scenario

- There are four groups of control signals:
 - Control signals for inverters output,
 - Control signals for water chillers return temperature,
 - Control signals for heating/cooling pipelines (per heat center) forward medium temperature (valve control),
 - Control signals for electric heaters.

3SMART switch OFF scenario

- All of these signal groups can be turned off separately by the software switch. After the signal is turned off the controlled units behave according to this:
 - Inverter: the output setpoint goes back to 100%. Value can be modified manually via the inverter's web interface.
 - Water chiller: the setpoint for the return temperature goes to a predefined value. Value can be modified manually via the chiller's control panel.
 - Valve: the original control system gets back the control possibility for the valve.
 - Electric heaters: the heaters will follow setpoint from the room controllers (user request).



3SMART ,crash' scenario

- All of these signal groups can be turned off separately by the software switch. After the signal is turned off the controlled units behave according to this:
 - Inverter: the output setpoint stays at the last value. Value can be modified manually via the inverter's web interface.
 - Water chiller: the setpoint for the return temperature stays at the last value. Value can be modified manually via the chiller's control panel.
 - Valve: the original control system gets back the control possibility for the valve.
 - Electric heaters: the heaters will follow setpoint from the room controllers (user request).



Grid-side installation



Grid side installations - summary

Grid side developments were elaborated mainly on software side, so it wasn't needed to make major physical installations, except for the smart meters.

Content:

- DA and ID prices data collection
- Smart meters, measurement on the grid
- IT platform (SCADA)
- Qlik – Business Intelligence tool for analysis



Grid side investment-DA and ID prices

- Market prices are key elements in the pilot in order to have the cost function for optimization on building side, so automated data sending has been established between the electricity market and the 3Smart system. A script has been developed on the side of EON, for sending market prices in an automated way (scheduled e-mails). Two types of price tables are sent to the EMS system: day-ahead and intra-day price tables:

List: States and values - Day-Ahead - E.ON 3Smart

ID	Send date	UTC Time	Trade day	Hour	Purchase price
1	2018-05-27 13:05:20	2018-05-27 23:00:00	2018-05-28	1	35.6
2	2018-05-27 13:05:20	2018-05-28 00:00:00	2018-05-28	2	32.62
3	2018-05-27 13:05:20	2018-05-28 01:00:00	2018-05-28	3	31.1
4	2018-05-27 13:05:20	2018-05-28 02:00:00	2018-05-28	4	30.4
5	2018-05-27 13:05:20	2018-05-28 03:00:00	2018-05-28	5	30.9
6	2018-05-27 13:05:20	2018-05-28 04:00:00	2018-05-28	6	34.35
7	2018-05-27 13:05:20	2018-05-28 05:00:00	2018-05-28	7	46.1
8	2018-05-27 13:05:20	2018-05-28 06:00:00	2018-05-28	8	54.3
9	2018-05-27 13:05:20	2018-05-28 07:00:00	2018-05-28	9	57.7
10	2018-05-27 13:05:20	2018-05-28 08:00:00	2018-05-28	10	53.0
11	2018-05-27 13:05:20	2018-05-28 09:00:00	2018-05-28	11	50.16
12	2018-05-27 13:05:20	2018-05-28 10:00:00	2018-05-28	12	49.5
13	2018-05-27 13:05:20	2018-05-28 11:00:00	2018-05-28	13	47.82
14	2018-05-27 13:05:20	2018-05-28 12:00:00	2018-05-28	14	46.6
15	2018-05-27 13:05:20	2018-05-28 13:00:00	2018-05-28	15	45.84
16	2018-05-27 13:05:20	2018-05-28 14:00:00	2018-05-28	16	47.21
17	2018-05-27 13:05:20	2018-05-28 15:00:00	2018-05-28	17	49.03
18	2018-05-27 13:05:20	2018-05-28 16:00:00	2018-05-28	18	52.5
19	2018-05-27 13:05:20	2018-05-28 17:00:00	2018-05-28	19	55.93

Day-ahead prices (DA)

List: States and values - Intraday - E.ON 3Smart

ID	Send date	UTC Time	Trade day	Quarter	Purchase price	Purchase volume	Selling price	Selling volume
125	2018-05-27 00:00:00	2018-05-27 05:15:00	2018-05-27	29	9.4	25.0	59.22	25.0
126	2018-05-27 00:00:00	2018-05-27 05:30:00	2018-05-27	30	9.4	25.0	59.22	25.0
127	2018-05-27 00:00:00	2018-05-27 05:45:00	2018-05-27	31	9.4	25.0	59.22	25.0
128	2018-05-27 00:00:00	2018-05-27 06:00:00	2018-05-27	32	9.4	25.0	59.22	25.0
129	2018-05-27 00:00:00	2018-05-27 06:15:00	2018-05-27	33	10.31	25.0	64.95	25.0
130	2018-05-27 00:00:00	2018-05-27 06:30:00	2018-05-27	34	10.31	25.0	64.95	25.0
131	2018-05-27 00:00:00	2018-05-27 06:45:00	2018-05-27	35	10.31	25.0	64.95	25.0
132	2018-05-27 00:00:00	2018-05-27 07:00:00	2018-05-27	36	10.31	25.0	64.95	25.0
133	2018-05-27 00:00:00	2018-05-27 07:15:00	2018-05-27	37	11.2	25.0	70.56	25.0
134	2018-05-27 00:00:00	2018-05-27 07:30:00	2018-05-27	38	11.2	25.0	70.56	25.0
135	2018-05-27 00:00:00	2018-05-27 07:45:00	2018-05-27	39	11.2	25.0	70.56	25.0
136	2018-05-27 00:00:00	2018-05-27 08:00:00	2018-05-27	40	11.2	25.0	70.56	25.0
137	2018-05-27 00:00:00	2018-05-27 08:15:00	2018-05-27	41	11.52	25.0	72.59	25.0
138	2018-05-27 00:00:00	2018-05-27 08:30:00	2018-05-27	42	11.52	25.0	72.59	25.0
139	2018-05-27 00:00:00	2018-05-27 08:45:00	2018-05-27	43	11.52	25.0	72.59	25.0
140	2018-05-27 00:00:00	2018-05-27 09:00:00	2018-05-27	44	11.52	25.0	72.59	25.0
141	2018-05-27 00:00:00	2018-05-27 09:15:00	2018-05-27	45	11.91	25.0	75.03	25.0
142	2018-05-27 00:00:00	2018-05-27 09:30:00	2018-05-27	46	11.91	25.0	75.03	25.0
143	2018-05-27 00:00:00	2018-05-27 09:45:00	2018-05-27	47	11.91	25.0	75.03	25.0

Intraday prices(ID)



Grid side investment-DA and ID prices

- Day-ahead table is sent once a day, at 13, with hourly prices for the next day, and intra-day tables are sent four times a day with quarter-hourly prices for the next hours. The tables arrive in csv format by mail, and integration to the database is automated

Day-ahead and Intraday prices



GUI displays both the day-ahead and intra-day information




Grid side investment- Smart metering

- One meter has been installed on LV (Low Voltage) side of the Kossuth st. transformer station, which is measuring the total electrical consumption of the pilot building. Two meters, one main and one control meter, have been installed on the MV (Medium Voltage) side of the Klaipeda tr. station, and these are measuring the total load of the MV line.



LV measurement in MV/LV Tr. St. Kossuth u.




MV measurement in MV/LV Tr. St Klaipeda



Grid side investment- Smart metering

- The smart meter is capable to collect one minute resolution data and communicates with the meter reading center. The biggest challenge was of the communication since instead of the traditional 15 minutes resolution we had to handle the one minute data resolution. Instead of 96 data/day we need to handle 1440 data/day.



Grid side investment- Smart metering

- The smart meter was integrated into the E.ON Smart meter reading center. The main challenge was the communication and data transfer between E.ON Smart meter reading center and 3Smart local server (IT platform for data acquisition).

Mérési adatok	Lokális Idő	Virtuális mérő							
		3SMART_ETI_kozpont_Debrecen_Kossuth							
		+A_LP2		L1 fesz		L2 fesz		L3 fesz	
		Aktuális adatok		Aktuális adatok		Aktuális adatok		Aktuális adatok	
		Normál érték	S.	Normál érték	S.	Normál érték	S.	Normál érték	S.
Adatvezérlés									
Adatforrás									
Virtuális mérő									
Adatkészülék									
3SMART_ETI_kozpont_Debrecen_Kossuth									
<input checked="" type="checkbox"/> +A_LP2 (Profil, 1 perc)	2018.03.05. 06:28:00	0,995		239,700		239,100		238,400	
<input type="checkbox"/> Alarm (Profil, 1 perc)	2018.03.05. 06:29:00	1,002		239,700		239,000		238,500	
<input type="checkbox"/> Cos_FI (Profil, 1 perc)	2018.03.05. 06:30:00	0,997		239,600		239,000		238,400	
<input type="checkbox"/> Frekvencia (Profil, 1 perc)	2018.03.05. 06:31:00	1,078		239,900		239,300		238,700	
<input checked="" type="checkbox"/> L1 fesz (Profil, 1 perc)	2018.03.05. 06:32:00	1,083		239,900		239,200		238,600	
<input checked="" type="checkbox"/> L2 fesz (Profil, 1 perc)	2018.03.05. 06:33:00	1,120		239,700		238,900		238,400	
<input checked="" type="checkbox"/> L3 fesz (Profil, 1 perc)	2018.03.05. 06:34:00	1,045		239,600		239,000		238,500	
További források kiválasztása	2018.03.05. 06:35:00	1,147		239,600		238,900		238,500	
Terhelési görbe 1 perc (7)	2018.03.05. 06:36:00	1,140		239,200		238,500		238,300	
Kiválasztás megszüntetése	2018.03.05. 06:37:00	1,190		239,500		238,600		238,200	
Adatoszlopok	2018.03.05. 06:38:00	1,260		239,400		238,600		238,000	
Pillanatfelvételi adatok	2018.03.05. 06:39:00	1,153		239,200		238,500		237,900	
Adatintervallum	2018.03.05. 06:40:00	1,107		239,400		238,600		237,900	
Kezdő időpont 2018.03.05. 00:00	2018.03.05. 06:41:00	1,055		239,100		238,400		237,700	
Befejező időpont 2018.03.06. 10:01	2018.03.05. 06:42:00	1,100		238,900		238,300		237,700	
Nap	2018.03.05. 06:43:00	1,133		239,200		238,500		237,900	
Hónap	2018.03.05. 06:44:00	1,168		239,000		238,300		237,800	
Hét	2018.03.05. 06:45:00	1,163		239,100		238,300		237,900	
Év	2018.03.05. 06:46:00	1,135		239,000		238,200		237,700	
<input type="radio"/> Időtartam beállítása a kezdő időtől	2018.03.05. 06:47:00	1,223		238,900		238,100		237,700	
<input checked="" type="radio"/> Időtartam beállítása a befejező időig	2018.03.05. 06:48:00	1,135		238,900		238,200		237,700	
Adatok lekérdes	2018.03.05. 06:49:00	1,232		238,900		238,100		237,700	
Státuszbiték	2018.03.05. 06:50:00	1,235		239,200		238,200		237,900	
Adatforrás paletta	2018.03.05. 06:51:00	1,247		241,600		240,700		240,200	
Érték hozzáadása	2018.03.05. 06:52:00	1,220		241,700		240,600		240,300	
Parancsok	2018.03.05. 06:53:00	1,250		241,500		240,500		240,000	

E.ON Smart meter reading center- Landis Converge system



IT platform for data acquisition/control

The IT platform covers a framework system which can be further developed. The main task of the platform is data collection from both the grid side and building side equipments and control of specific equipment in the building (modules developed by universities serve the basis of the control, but this platform will execute the command).

- Users can change temperature setpoint in the rooms where electrical heating is installed via the unit installed on the wall. The 3Smart system will take into consideration that setpoint while optimizing the building operation.
- In the rooms where fan coils are installed users can change the temperature setpoint via the original controllers. This information will not be collected by the 3Smart system.
- Internal web-based interface (system administrators): there are two separate systems which provides access to the test site. The first one is only available inside the 3Smart network and EON's network. This SCADA system provides supervision and control tool via intranet website. Through that site all current and historical data is available. It also provides all the required control possibilities including the software switches.



IT platform for data acquisition/control

E.ON 3Smart Home Config data States and values Commands and alerts Administration Gábor



E.ON 3Smart projekt

A projekt a Duna Transznacionális Programból, az Európai Regionális Fejlesztési Alap támogatásával, az Európai Unió és Magyarország társfinanszírozásával valósul meg.


Choose a language



IT platform for data acquisition/control

E.ON 3Smart Home **Config data** States and values **Commands and alerts** Administration **Gábor**

List: States and values - Zone heat map - E.ON 3Smart



IT platform for data acquisition/control

E.ON 3Smart

Home

Config data -

States and values -

Commands and alerts -

Administration -

Gábor -

List: States and values - RT measures - E.ON 3Smart

List (372)	Export	Add Filter -	Search					
	Last time	Last time	Equipment code	Measured attr code	E.ON code	Building	Floor	Last value
	2019-01-30 06:16:59	Equipment code	168.2.114/1-1-96	ZI1	D VIRT	D	-1	25.45
	2019-01-30 06:16:59	Measured attr code	168.2.114/1-1-96/1	ZI2	D VIRT	D	-1	31.15
	2019-01-30 06:16:59	E.ON code	168.2.123/1-1-123	ZI1	A38	A	2	19.75
	2019-01-30 06:16:59	Building	168.2.123/1-1-123/1	ZI2	A38	A	2	27.75
	2019-01-30 06:16:59	Floor	192.168.2.130/1-1-124	ZI1	D73	D	2	22.45
	2019-01-30 06:16:59	Last value	192.168.2.130/1-1-124/1	ZI2	D73	D	2	44.95
	2019-01-30 06:16:59		192.168.2.124/1-1-101	ZI1	A28	A	2	23.85
	2019-01-30 06:16:59		192.168.2.124/1-1-101/1	ZI2	A28	A	2	33.15
	2019-01-30 06:16:59		192.168.2.117/1-1-116	ZI1	B66	B	1	25.35
	2019-01-30 06:16:59		192.168.2.117/1-1-116/1	ZI2	B66	B	1	42.55
	2019-01-30 06:16:59		192.168.2.116/1-1-117	ZI1	C03	C	3	22.95
	2019-01-30 06:16:59		192.168.2.116/1-1-117/1	ZI2	C03	C	3	47.05
	2019-01-30 06:16:59		192.168.2.122/1-1-121	ZI1	A39	A	2	20.55
	2019-01-30 06:16:59		192.168.2.122/1-1-121/1	ZI2	A39	A	2	31.05




IT platform for data acquisition/control


E.ON 3Smart Home Config data ▾ States and values ▾ Commands and alerts ▾ Administration ▾ Gábor ▾

List: States and values - HVAC - E.ON 3Smart

[A State now]



[B+C State now]



IT platform for data acquisition/control

E.ON 3Smart Home **Config data** States and values Commands and alerts Administration **Gabor**

Edit: Commands and alerts - Edit command template - E.ON 3Smart

List Create **Edit** Details

Equ type * Frontier PV inverter

Command code * PVO

Raw command *

```
"schema": {
  "parts": {
```

Modul leállás esetén kiadandó

Parancs modul leállás esetén

```
{"parts": [{"start_register": "40242", "data_structure": "16bit_uint", "length": "1", "value": "@", "mapping": "lambda x: x*100"}, {"start_register": "40246", "
```

Érték modul leállásra 100

Save Save and Add Another Save and Continue Editing **Cancel**


Powered by Nextent



Data visualisation based on IT platform


Analytical and visualization tool for the 3Smart system – Qlik (system administrators)

- This software is a second interface for the 3Smart system. This software is a business intelligence application for analysis and visualization based on historical data. The application uses the 3Smart database, reads the data once a day. The most recent data available is always from the previous day.
- This is a web-based application (thin client), no installation is needed and can be accessed by using a secure connection. Hungarian and English language is available.
- The Qlik software supports benchmarking and technical analysis.
- The user-friendly design allows many ways for the analyst to prepare relevant and detailed reports and analyses.



Data visualisation based on IT platform


[EON] eon3smart_nextent




[EON] eon3smart_nextent
 Data last loaded: Jan 28, 2019, 12:49 PM
 Published: Jul 4, 2018, 1:53 PM
 Published to: EON

Sheets | Bookmarks | Stories Create new sheet

▼ Base sheets (34)




DANUBE TRANSNATIONAL...




Summary


Foundations:




Measured Quantities




Locations




Equipments




Measured Data Review




Room temperatures (wit...




Room temperature Heatmap




Room temperature Treemap




Correlation




Statistical analysis of room ...




Day-ahead and Intraday prices




Prices table




Weather - forecast vs measured ...




Weather forecast - sun radiation



PV Inverter




Comparison of PV Inverter outputs




PV Inverter daily output cs sun ...




Data visualisation based on IT platform



Data visualisation based on IT platform



Data visualisation based on IT platform



* The data set contains negative or zero values that cannot be shown in this chart.



Connection with grid side modules

Originally Short term and Long term grid side modules were planned to integrate into the IT platform, but finally both kind of grid side module were handled separately from development and application point of view.

- **Long term:** separated application and workflow, in connection with 3Smart database
- **Short term:** separated softwares (Neplan, Gurobi, Plotly) and codes in connection with 3Smart database

We can follow and monitor the behaviour of the building and see the context between the grid and building side operation through the IT platform and Qlik.



On-line demonstration of basic IT infrastructure performance with the installed equipment

Andras Mucsi/Gabor Papp

University of Debrecen/EON Tiszántúli Áramhálózati Zrt.

mucsi.andras@science.unideb.hu

First pilot study visit to the Hungarian pilot

February 5-6, 2019.




























SCADA – Equipment list

E.ON 3Smart [Kezdőlap](#) [Törzsadatok](#) [Állapotok és értékek](#) [Parancsok és riasztások](#) [Adminisztráció](#) [András](#)

List: Törzsadatok - Eszközök - E.ON 3Smart

Lista (158) [Létrehozása](#) [Exportálás](#) [Szűrő hozzáadása](#) [A kiválasztott](#)

<input type="checkbox"/>		Azonosító	Név	Eszköz kód	IP cím	Alcím	Típus	Modul	Szoba
<input type="checkbox"/>	  	1	ROOM_TEMP 5C:CF:7F:30:5C:E6 E85 D VIRT (0/2/0)	192.168.2.114/1-1-96	192.168.2.114	0	Szoba hőmérséklet mérő	ZONE	D VIRT
<input type="checkbox"/>	  	2	ROOM_TEMP 5C:CF:7F:30:5C:C2 A38 (0/1/0)	192.168.2.123/1-1-123	192.168.2.123	0	Szoba hőmérséklet mérő	ZONE	A38
<input type="checkbox"/>	  	3	ROOM_TEMP 5C:CF:7F:30:5C:C4 D73 (0/1/0)	192.168.2.130/1-1-124	192.168.2.130	0	Szoba hőmérséklet mérő	ZONE	D73
<input type="checkbox"/>	  	4	ROOM_TEMP 5C:CF:7F:30:5C:C5 A28 (0/1/0)	192.168.2.124/1-1-101	192.168.2.124	0	Szoba hőmérséklet mérő	ZONE	A28
<input type="checkbox"/>	  	5	ROOM_TEMP 5C:CF:7F:30:5C:C6 B91 (0/0/0)	192.168.2.143/1-1-97	192.168.2.143	0	Szoba hőmérséklet mérő	ZONE	B91
<input type="checkbox"/>	  	8	ROOM_TEMP 5C:CF:7F:30:5E:A5 B66 (0/1/0)	192.168.2.117/1-1-116	192.168.2.117	0	Szoba hőmérséklet mérő	ZONE	B66
<input type="checkbox"/>	  	9	ROOM_TEMP 5C:CF:7F:30:5E:A7 C03 (0/1/0)	192.168.2.116/1-1-117	192.168.2.116	0	Szoba hőmérséklet mérő	ZONE	C03
<input type="checkbox"/>	  	10	ROOM_TEMP 5C:CF:7F:30:5E:A8 A39 (0/1/0)	192.168.2.122/1-1-121	192.168.2.122	0	Szoba hőmérséklet mérő	ZONE	A39
<input type="checkbox"/>	  	11	ROOM_TEMP 5C:CF:7F:30:5E:AC E32 (0/0/0)	192.168.2.149/1-1-106	192.168.2.149	0	Szoba hőmérséklet mérő	ZONE	E32
<input type="checkbox"/>	  	13	ROOM_TEMP 5C:CF:7F:30:60:A2 D29 (0/1/0)	192.168.2.150/1-1-107	192.168.2.150	0	Szoba hőmérséklet mérő	ZONE	D29



SCADA – Location list

E.ON 3Smart [Kezdőlap](#) [Törzsadatok](#) [Állapotok és értékek](#) [Parancsok és riasztások](#) [Adminisztráció](#) [András](#)

List: Törzsadatok - Helyszínek - E.ON 3Smart

Lista (374)	Létrehozása	Exportálás	Szűrő hozzáadása	A kiválasztott	Keresés								
	Azonosító	Név	E.ON kód	Épület	Emelet	Alapterület	Belmagasság	Funkció	X koordináta	Y koordináta			
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1	A01 Pinceklub	A01	A	-1	74.93	2.4	Szociális helyiség	2680	1220
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	2	A02 Raktár	A02	A	-1	7.26	2.4	Raktár	2500	1370
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	3	A04 Lépcső	A04	A	-1	6.39	2.4	Közlekedő terek	2570	1330
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4	A05/1 Bejárat - szélfogó	A05/1	B	0	5.6	3.8	Közlekedő terek	2620	525
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5	A.1 Iroda	A05	A	0	22.46	3.8	Iroda	2700	1330
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	6	A.2 Iroda	A06	A	0	18.76	3.8	Iroda	2720	1445
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	7	A07 Női Wc	A07	A	0	9.2	3.8	Iroda	2575	1450
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	8	A08 Raktár	A08	A	0	3.46	3.8	Raktár	2625	1455
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	9	A09 FF Wc	A09	A	0	9.54	3.8	Szociális helyiség	2480	1450
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	10	A10 Folyosó	A10	A	0	25.33	3.8	Közlekedő terek	2570	1350
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	11	A11 Nagytanácsterem	A11	C	0	166.69	3.3	Tárgyaló	2185	1175
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	12	A12 Ruhatár	A12	A	0	17.61	3.8	Szociális helyiség	2700	1245
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	13	A13 Lépcső	A13	A	1	19.17	3.75	Közlekedő terek	2430	1360
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	14	A.101 Iroda	A14	A	1	12.82	3.75	Iroda	2510	1460
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	15	A.102 Iroda	A15	A	1	21.27	3.75	Iroda	2710	1460

SCADA – Current measured values

E.ON 3Smart [Kezdőlap](#) [Törzsadatok](#) [Állapotok és értékek](#) [Parancsok és riasztások](#) [Adminisztráció](#) [András](#)

List: Állapotok és értékek - Pillanatnyi adatok - E.ON 3Smart


Lista (372)	Exportálás	Szűrő hozzáadása	Keresés				
	Utolsó mérés időpontja	Eszköz kód	Mért jellemző kódja	E.ON kód	Épület	Emelet	Utolsó mért érték
	2019-02-12 09:31:40	192.168.0.34:502/34	HSI4	E VIRT	E	-1	31.3696
	2019-02-12 09:31:40	192.168.0.34:502/31	HSI4	A VIRT	A	-1	20.6175
	2019-02-12 09:31:40	192.168.0.34:502/33	HSI4	D VIRT	D	-1	18.2831
	2019-02-12 09:31:41	192.168.0.34:502/64	HSI5	E VIRT	E	-1	25.0
	2019-02-12 09:31:41	192.168.0.34:502/62	HSI5	B+C VIRT	B	-1	41.0
	2019-02-12 09:31:41	192.168.0.34:502/63	HSI5	D VIRT	D	-1	27.0
	2019-02-12 09:31:42	192.168.0.36:502/101	WSI5				320.0
	2019-02-12 09:31:42	192.168.0.36:502/102	WSI4				4.0
	2019-02-12 09:31:43	192.168.0.36:502/104	WSI1				277.0
	2019-02-12 09:31:43	192.168.0.36:502/105	WSI2				220.0
	2019-02-12 09:31:43	192.168.0.36:502/103	WSI3				5.2
	2019-02-12 09:31:44	192.168.0.36:502/103	WSI6				999.9
	2019-02-12 09:31:44	192.168.0.36:502/103	WSI7				70.5
	2019-02-12 09:31:45	192.168.0.35:502/255	PMI1				161523.0
	2019-02-12 09:31:45	192.168.0.34:502/62	CHI1	B+C VIRT	B	-1	64.9525



SCADA – 3D map of values

E.ON 3Smart Kezdőlap Törzsadatok ▾ **Állapotok és értékek ▾** Parancsok és riasztások ▾ Adminisztráció ▾ András ▾

List: Állapotok és értékek - Hőterkép - E.ON 3Smart




SCADA – Heat center view

E.ON 3Smart Kezdőlap Törzsadatok **Állapotok és értékek** Parancsok és riasztások Adminisztráció András

List: Állapotok és értékek - Hőközpontok - E.ON 3Smart

[A központ pillanatnyi állapota]



SCADA – Commands

E.ON 3Smart

Kezdőlap

Törzsadatok ▾



Állapotok és értékek ▾

Parancsok és riasztások ▾

Adminisztráció ▾

András ▾

List: Parancsok és riasztások - Parancs sablonok szerkesztése - E.ON 3Smart

Lista (8)		Létrehozása	Szűrő hozzáadása ▾	A kiválasztott ▾	Keresés			
<input type="checkbox"/>		Azonosító	Parancs kódja	Eszköz típus	Nyers parancs struktúra	Modul leállítás esetén kiadandó	Érték modul leállításra	Parancs modul leállítás esetén
<input type="checkbox"/>	  	2	PVO	Frontier PV inverter	<pre>"schema": { "parts": { "type": "array", "items": { "type": "object", "properties": { "start_register": { "type": "hidden", "value": { "type": "integer", "title": "{{idx}. Value", "length": { "type": "hidden", "data_structure": { "type": "hidden", "mapping": { "type": "hidden" } } } }, "value": { "parts": [{ "start_register": 40242, "value": 100, "length": 1, "data_structure": "16bit_uint", "mapping": "lambda x: x*100", { "start_register": 40246, "value": 0, "length": 1, "data_structure": "16bit_int", "mapping": "lambda x: x", { "start_register": 40246, "value": 1, "length": 1, "data_structure": "16bit_int", "mapping": "lambda x: x" }] } } } } }</pre>	<input checked="" type="checkbox"/>	100	<pre>{ "parts": [{ "start_register": "40242", "data_structure": "16bit_uint", "length": "1", "value": "@, "mapping": "lambda x: x*100", { "start_register": "40246", "data_structure": "16bit_int", "length": "1", "value": 0, "mapping": "lambda x: x", { "start_register": "40246", "data_structure": "16bit_int", "length": "1", "value": 1, "mapping": "lambda x: x" }] }</pre>



SCADA – Module state (Software switch)

E.ON 3Smart Kezdőlap Törzsadatok ▼ Állapotok és értékek ▼ Parancsok és riasztások ▼ Adminisztráció ▼ András ▼

Edit: Adminisztráció - Modulok - E.ON 3Smart


Lista Szerkesztése Részletek

Modul állapota


Mentés Mentés és szerkesztés folytatása Mégse

Powered by Nextent

Qlik – BI tool for visualization and analytics



Qlik – BI tool for visualization and analytics



Qlik – BI tool for visualization and analytics

The screenshot shows the Qlik BI tool interface. At the top, there is a menu bar with options like 'Fájl', 'Nyomtatás', 'E-mail', 'Írás', and 'Megnyitás'. Below the menu is a toolbar with icons for home, list, and search, along with a search bar containing '[EON] eon3smart_nextent'. The main area displays four key metrics: 'Equipments' (158), 'Number of measurements' (117.3M), 'Measured quantity types' (41), and 'Foundations' (2018-06-14 02:00:00 to 2019-02-04 12:03:00). The interface is clean and modern, with a blue header and a white background.

Equipments

158

Number of measurements

117.3M

Measured quantity types

41

First date


2018-06-14 02:00:00

Last date

2019-02-04 12:03:00



Qlik – BI tool for visualization and analytics



Qlik – BI tool for visualization and analytics

Fájl ▾ Nyomtatás ▾ E-mail Írás ▾ Megnyitás ▾

[EON] eon3smart_nextent

[EON] eon3smart_nextent
 Data last loaded: Feb 4, 2019, 12:22 PM
 Published: Jul 4, 2018, 1:53 PM
 Published to: EON

Sheets | Bookmarks | Stories

Create new sheet

▼ Base sheets (34)

- DANUBE TRANSNATIONAL...
- Foundations
- Measured Quantities
- Locations
- Equipments
- Measured Data Review
- Room temperatures (wit...
- Room temperature Heatmap
- Room temperature Treemap
- Correlation
- Statistical analysis of room ...
- Day-ahead and Intraday prices
- Prices table
- Weather - forecast vs measured ...
- Weather forecast - sun radiation
- PV Inverter



Qlik – BI tool for visualization and analytics

Fájl Nyomtatás E-mail Írás Megnyitás

[EON] eon3smart_nextent

Location Building Location Floor

Locations

Location Building	Location Floor	Location Name	Location Function	Equipment Type	Equipment Name	Location Height	Room volume
Totals						2.7	740.31
B91	Iroda	B	2	B.206 Iroda		2.7	107.62
B89	Iroda	B	2	B.207 Iroda		2.7	213.95
B95	Iroda	B	2	B.208 Igazgatói iroda		2.7	93.07
B88	Iroda	B	2	B.211 Iroda		2.7	45.28
B72	Közlekedő terek	B	2	B72 Lépcsőház		2.7	32.86
B90	Raktár	B	2	B90 Raktár		2.7	6.02
B92	Tárgyaló	B	2	B92 Tárgyaló		2.7	97.82
B93	Közlekedő terek	B	2	B93 Előtér		2.7	19.36
B94	Szociális helyiség	B	2	B94 Tea konyha		2.7	25.52
B96	Közlekedő terek	B	2	B96 Előtér		2.7	67.18
BA8	Közlekedő terek	B	2	BA8 Loggia		2.7	7.43
BA9	Szociális helyiség	B	2	BA9 FF We		2.7	24.22
B95A	Iroda	B	2	Ismeretlen 3			0.00
B95B	Iroda	B	2	Ismeretlen 4			0.00

Search Szoba hőmérséklet mérő
 CIAT Carel
 CIAT Connect 1
 CIAT MR 1
 DIRIS A40 E INF fogyasztásmérő
 DIRIS A40 FC fogyasztásmérők
 DIRIS A40 HVAC fogyasztásmérő 2
 DIRIS A40 HVAC fogyasztásmérők



Qlik – BI tool for visualization and analytics



Qlik – BI tool for visualization and analytics



Short term modules coordination on the sides of E.ON


Tomislav Capuder/ Paula Mamić /Mirna Gržanić

University of Zagreb Faculty of Electrical Engineering and Computing

Tomislav.capuder@fer.hr; paula.mamic@fer.hr; mirna.grzanic@fer.hr

3Smart – First pilot visit Debrecen

05. – 06.02.2019



Project co-funded by the European Union

Content

- Short-term Day-ahead module
 - Model architecture
 - Database overview
 - Communication model
- Short-term Intra-day module
 - Model architecture
 - Database overview
 - Communication model

SHORT TERM DAY-AHEAD MODULE



Short-term Day-Ahead Module

- Day – to – day operation module for determining building flexibility potential as the distribution network/system operator asset:
 - Interconnection with long term module and receiving flexibility requirements
 - Defined flexibility requirements in long term module are set as maximum value bound in short term DA module
 - AC OPF in Python (Gurobi solver) is run daily to define HOW MUCH (from 0 to max reserved capacity) of the reserved flexibility capacity will be activated the next day (bound by long term contract)

ST Day-Ahead Module Input

- Neplan project (.nepprj):
 - Neplan_extension.dll *runs load-flow analysis with profiles* and exports results and grid information in MySQL
 - Prepare data for ACOPF
 - Neplan conditions:
 - Radial network with one-feeder
 - Lines, nodes and substations named with short-label and index from 0 to n

ST Day-Ahead Module Input (1)

- From Neplan:
 - Grid information (grid topology, lines descriptions)
 - Active and reactive power profiles for every node defined for specific days during the year (3 characteristics profiles for each moth)
- From Long-term contract:
 - Building flexibility table

Module coordination

- Day before delivery of electricity
 - At **11.00 AM** (UTC) HUPX publish (at 10:40 UTC) the Day-Ahead prices
 - „Retailer” gather the data, extend hourly prices to 15 min prices, convert prices to EUR/kWh and **store** into table „Retailer to building DA prices” in „Retailer” DB

Retailer database outlook

retailer on postgres@3s_grid

```
1 SELECT * FROM public.retailer_to_building_da_prices
2
```

Data Output	Explain	Messages	Notifications	Query History
id [PK] integer	retailer_id integer	profile character varying (2000)	profile_created_at timestamp without time zone	
1	7	{ "DA prices": [0.0437, 0.0437,...	2019-02-03 11:48:50.887972	

{ "DA prices": [0.0437, 0.0437, 0.0437, 0.0437, 0.04137, 0.04137, 0.04137, 0.04137, 0.04048, 0.04048, 0.04048, 0.04048, 0.03921, 0.03921, 0.03921, 0.03921, 0.03855, 0.03855, 0.03855, 0.03855, 0.04072, 0.04072, 0.04072, 0.04072, 0.04923, 0.04923, 0.04923, 0.04923, 0.07315, 0.07315, 0.07315, 0.07315, 0.07963, 0.07963, 0.07963, 0.07963, 0.08009, 0.08009, 0.08009, 0.08009, 0.07233, 0.07233, 0.07233, 0.07233, 0.067, 0.067, 0.067, 0.067, 0.06178, 0.06178, 0.06178, 0.06178, 0.06104, 0.06104, 0.06104, 0.06104, 0.06481, 0.06481, 0.06481, 0.06481, 0.06495, 0.06495, 0.06495, 0.06495, 0.06815, 0.06815, 0.06815, 0.06815, 0.06815, 0.10107, 0.10107, 0.10107, 0.10107, 0.07727, 0.07727, 0.07727, 0.07727, 0.07066, 0.07066, 0.07066, 0.07066, 0.06623, 0.06623, 0.06623, 0.06623, 0.0441, 0.0441, 0.0441, 0.0441, 0.0431, 0.0431, 0.0431, 0.0431, 0.0361, 0.0361, 0.0361, 0.0361], "Measuring unit": "EUR/kWh", "Valid from": "2019-02-03 23:00:00"}

```
1 SELECT * FROM public.retailer_to_building_da_prices
2
```

Data Output	Explain	Messages	Notifications	Query History
id [PK] integer	retailer_id integer	profile character varying (2000)	profile_created_at timestamp without time zone	
11	19	{ "DA prices": [0.04202, 0.042...	2019-01-07 17:30:05.478255	
12	20	{ "DA prices": [0.06251, 0.062...	2019-01-08 17:30:05.478251	
13	21	{ "DA prices": [0.05846, 0.058...	2019-01-09 17:30:05.478278	
14	22	{ "DA prices": [0.06166, 0.061...	2019-01-10 17:30:05.4782	
15	23	{ "DA prices": [0.0651, 0.0651...	2019-01-11 17:30:05.51782	
16	24	{ "DA prices": [0.06344, 0.063...	2019-01-12 17:30:05.51782	
17	25	{ "DA prices": [0.05306, 0.053...	2019-01-13 17:30:05.51782	
18	26	{ "DA prices": [0.06214, 0.062...	2019-01-14 17:30:05.51782	
19	27	{ "DA prices": [0.06669, 0.066...	2019-01-15 17:30:05.51782	
20	28	{ "DA prices": [0.08001, 0.080...	2019-01-16 17:30:05.51782	
21	29	{ "DA prices": [0.06015, 0.060...	2019-01-17 17:30:05.51782	
22	30	{ "DA prices": [0.065, 0.065, 0...	2019-01-18 17:30:05.51782	
23	31	{ "DA prices": [0.06669, 0.066...	2019-01-19 17:30:05.51782	
24	32	{ "DA prices": [0.059, 0.059, 0...	2019-01-20 17:30:05.51782	
25	33	{ "DA prices": [0.07148, 0.071...	2019-01-21 17:30:05.51782	
26	34	{ "DA prices": [0.06157, 0.061...	2019-01-22 17:30:05.51782	
27	35	{ "DA prices": [0.06473, 0.064...	2019-01-23 17:30:05.51782	
28	41	{ "DA prices": [0.06463, 0.064...	2019-01-24 16:09:49.365266	
29	42	{ "DA prices": [0.06463, 0.064...	2019-01-24 16:10:04.599151	
30	43	{ "DA prices": [0.06463, 0.064...	2019-01-24 17:44:04.28671	
31	44	{ "DA prices": [0.06463, 0.064...	2019-01-24 20:27:32.337022	
32	45	{ "DA prices": [0.06463, 0.064...	2019-01-24 20:33:02.049466	
33	46	{ "DA prices": [0.06463, 0.064...	2019-01-24 20:33:22.226096	
34	47	{ "DA prices": [0.06463, 0.064...	2019-01-25 20:34:29.984231	
35	48	{ "DA prices": [0.04464, 0.044...	2019-01-26 18:43:02.694897	
36	49	{ "DA prices": [0.04706, 0.047...	2019-01-27 19:15:46.874447	
37	50	{ "DA prices": [0.04976, 0.049...	2019-01-28 11:19:05.883031	
38	51	{ "DA prices": [0.04701, 0.047...	2019-01-29 19:11:24.47434	
39	52	{ "DA prices": [0.05322, 0.053...	2019-01-31 19:10:06.929731	
40	53	{ "DA prices": [0.05322, 0.053...	2019-02-01 10:28:52.450285	
41	54	{ "DA prices": [0.05016, 0.050...	2019-02-01 20:28:12.850834	
42	55	{ "DA prices": [0.04517, 0.045...	2019-02-02 22:01:37.274	
43	56	{ "DA prices": [0.0437, 0.0437...	2019-02-03 19:48:50.921561	

Retailer database outlook

```

retailer on postgres@3s_grid
1 SELECT * FROM public.retailer_to_building_da_prices
2


```

```

1 SELECT * FROM public.retailer_to_building_da_prices
2

```

{"DA price":
 0.04137,
 0.03921,
 0.04072,
 0.04923,
 0.07963,
 0.07233,
 0.06178,
 0.06481,
 0.06495,
 0.10107,
 0.07066,
 0.0441,
 0.0361,
 "from": "2



ID	DA prices	Timestamp
42	1 {"DA prices": [0.04517, 0.045...	2019-02-02 22:01:37.274
43	1 {"DA prices": [0.0437, 0.0437...	2019-02-03 19:48:50.921561

Module coordination

- At **12.00 AM (UTC)** **the building reads** the DA price profile from „Retailer” DB table „Retailer to building DA prices” and runs MPC
 - At **13.00 AM (UTC)** **the building stores** the result „Declared DA profile” in communication table „building_to_dso_declared_da_profiles”
 - **the DSO reads** the profile and stores in its own communication table when AC OPF is started

Database outlook

dso on postgres@3s_grid

```
1 SELECT * FROM public.building_to_dso_declared_da_profiles
2
```

Data Output	Explain	Messages	Notifications	Query History
id [PK] integer	building_id integer	profile character varying (3000)	profile_created_at timestamp without time zone	
1	1	{'declared_da_profile': [51.6...	2019-02-04 13:30:19.713084	

{'declared_da_profile': [51.622, 53.787000000000006, 54.728, 58.132, 56.885000000000005, 56.237, 56.932, 56.959, 56.596000000000004, 56.772000000000006, 56.534, 56.007999999999996, 56.077, 56.191, 55.366, 53.486000000000004, 53.236999999999995, 52.446, 52.844, 53.023999999999994, 52.607, 50.203, 50.539999999999999, 51.85, 61.81, 53.9, 51.726, 51.859, 46.728, 49.26, 49.483, 42.628, 42.387999999999999, 41.428, 41.141, 40.943, 40.899, 41.342, 41.481, 41.604, 41.799, 41.871, 41.931999999999995, 41.828999999999999, 41.973, 41.746, 41.933, 42.297, 42.455, 42.479, 42.7, 42.794, 42.647999999999996, 42.94, 42.772000000000006, 42.714, 42.843, 42.786, 42.863, 42.915, 42.968, 43.074, 42.943, 42.913, 42.979, 43.038, 43.254000000000005, 44.061, 43.275999999999996, 54.825, 58.078, 78.765999999999999, 74.7, 67.782000000000001, 69.033999999999999, 64.38, 59.166, 59.703999999999999, 60.242, 61.916000000000004, 63.428, 64.764000000000001, 62.852, 64.454000000000001, 61.600999999999999, 62.694, 63.524, 62.726000000000006, 60.739999999999995, 58.613, 58.803, 63.007999999999996, 60.995, 63.929, 70.607, 65.636], 'measuring_unit': 'kWh', 'valid_from': '2018-02-04 23:00:00'}

dso on postgres@3s_grid

```
1 SELECT * FROM public.building_to_dso_declared_da_profiles
2
```

Data Output	Explain	Messages	Notifications	Query History
id [PK] integer	building_id integer	profile character varying (3000)	profile_created_at timestamp without time zone	
1	1	{'valid_from': '2018-12-13 0...	2018-12-11 23:44:47.509918	
2	2	{'valid_from': '2018-12-13 0...	2018-12-11 23:47:49.023675	
3	3	{'valid_from': '2018-12-13 0...	2018-12-11 23:50:06.826921	
4	4	{'valid_from': '2018-12-13 0...	2018-12-11 23:55:11.779649	
5	5	{'valid_from': '2018-12-13 0...	2018-12-11 23:55:22.83317	
6	6	{'valid_from': '2018-12-13 0...	2018-12-11 23:57:14.576792	
7	7	{'valid_from': '2018-12-13 0...	2018-12-12 00:00:57.386639	
8	8	{'valid_from': '2018-12-13 0...	2018-12-12 00:02:05.532131	
9	9	{'valid_from': '2018-12-13 0...	2018-12-12 00:02:43.999425	
10	10	{'valid_from': '2018-12-13 0...	2018-12-12 00:04:34.190611	
11	11	{'valid_from': '2018-12-14 0...	2018-12-12 07:58:38.982417	
12	12	{'valid_from': '2018-12-14 0...	2018-12-12 07:59:01.930168	
13	13	{'valid_from': '2018-12-14 0...	2018-12-12 07:59:53.970276	
14	14	{'valid_from': '2018-12-14 0...	2018-12-12 08:00:50.930219	
15	15	{'measuring_unit': 'kWh', 'v...	2018-12-12 08:49:54.18283	
16	16	{'measuring_unit': 'kWh', 'v...	2018-12-12 08:50:35.589541	
17	17	{'measuring_unit': 'kWh', 'v...	2018-12-12 08:52:49.261845	
18	18	{'measuring_unit': 'kWh', 'v...	2018-12-12 08:53:39.052097	
19	19	{'measuring_unit': 'kWh', 'v...	2018-12-12 08:54:01.973951	
20	20	{'measuring_unit': 'kWh', 'v...	2018-12-12 08:55:39.557233	
21	21	{'measuring_unit': 'kWh', 'v...	2018-12-12 08:55:59.647734	
22	22	{'measuring_unit': 'kWh', 'v...	2018-12-12 08:57:00.642555	
23	23	{'declared_da_profile': [['52...	2018-12-12 11:32:01.992102	
24	24	{'declared_da_profile': [['52...	2018-12-12 11:41:21.440806	
25	25	{'declared_da_profile': [['51...	2018-12-12 11:43:16.914286	
26	26	{'declared_da_profile': [['51...	2018-12-12 11:43:59.42221	
27	27	{'declared_da_profile': [['51...	2018-12-12 11:44:42.520898	
28	28	{'declared_da_profile': [['51...	2018-12-12 11:48:12.730764	
29	29	{'declared_da_profile': [['51...	2018-12-12 11:48:29.35575	
30	30	{'declared_da_profile': [['51...	2018-12-12 11:52:39.251857	
31	31	{'declared_da_profile': [['51...	2018-12-12 11:53:00.102413	
32	32	{'declared_da_profile': [['50...	2018-12-12 13:06:46.425783	
33	33	{'declared_da_profile': [['50...	2018-12-12 13:07:24.688093	
34	34	{'valid_from': '2018-12-14 0...	2018-12-12 13:18:53.815162	

AC OPF module


- Input:

- Grid data ✓
- Load profiles ✓
- Long-term – building flexibility profiles ✓
- Building „Declared DA profile” ✓

Defined for the next day



- Output:

- Voltage and current state of network
- Building flexibility activation profile




AC OPF results

- Results visualised:
 - Voltage
 - Current
 - Active power
 - Reactive power




ST DA module results for 13/12/2018



Database schema

- Input tables for AC OPF
 - From Excel, Neplan, building and long term module
- Output tables – AC OPF results
 - For plotly and building
- Rest of communication tables
- Archive of communication tables



SHORT TERM INTRA-DAY MODULE



Short-term Intra-Day Module


- Intra-day operations allow DSO to improve day-ahead schedule with real time measurements and prices
 - ST ID module is interconnected with the long term contract, ST DA module and with SCADA measurements
- Focus: triggering flexibility through real-time measurements in case DA forecasts deviate from actual events
- ID flexibility is triggered only in case of imbalances (if the measured value is higher than the triggering value):
 - If such event occurs before the scheduled utilization of the flexibility coming from the day-ahead module
 - In case of unforecasted events or „specific” network conditions.

ST Intra-Day Module Input

- SCADA
 - Real time measurement from feeder
- AC OPF:
 - Predicted feeder consumption
 - DA flexibility activation profile
- Long term
 - Flexibility reservation profile

ST Intra-Day Module Coordination

- Day of delivery:




ST Intra-Day Module Logic

- Conditions:
 - Measurements $>$ predicted AND
 - Flexibility reservation (from LT) $>$ 0 AND
 - DA flexibility activation profile $<$ 0
 - Then it calculates ID triggering value

ST Intra-Day Module Results

Intra-Day operations for 13/12/2018



3Smart modules organization on the grid side

Katalin Décseiné Giczi/
Gábor Péter

EON Tiszántúli Áramhálózati Zrt.

k.giczi.decseine@eon-hungaria.com, gabor.peter1@eon-hungaria.com

3Smart – Pilot study visit- Debrecen
06. – 05.02.2019.



UNIVERSITY OF ZAGREB
FACULTY OF
ELECTRICAL
ENGINEERING
AND COMPUTING



Interreg 
Danube Transnational Programme
3Smart

The logo for E.ON, featuring the letters 'e.on' in a bold, red, italicized sans-serif font.

Grid side modules to be installed in Debrecen


- Annual Long term module -> ready, installed
- Multiannual Long term module -> ready, installed
- DA Short term module -> in progress
- ID short term module -> under development

LONG TERM (MULTI)ANNUAL MODULE



Installation package of LT module


Installation package was provided via Basecamp at the end of 2018.

 3Smart Long term module manual

 3Smart_LT module_v1

 dso_lt_v1

 Grid side database - LT v1


 Long Term Module Installation_v1

 Long-term communication between DSO and building as flexibility service provider

Technical requirement

- Linux Ubuntu or Windows
- Database (PostgreSQL or MySQL, or any database supported by python's SQLAlchemy), Hungarian implementation is using MySQL.
- Python 3.6.5
- MS Office – Excel (for local DSO users who will work with the LT excel (data filling, initiation of calculations) on local PC
- Microgrid database has to be accessible by Grid side database

Database structure



Operation of web based LT module

Long Term Workflow

Grid

Building

Contract

Step	Activity	Link	Status
1	[DSO staff] is calculating flexibility needs, prices, penalty and quality of service by using "3Smart_LT module_v1.xlsm"	Template	?
2	[DSO staff] is importing the results of "3Smart_LT module_v1.xlsm"	Import DSO Flex Table	?
3	[Building EMS Microgrid module] is fetching data from LT database		?
4	[Building EMS Microgrid module] is calculating flexibility offer		?
5	[DSO LT module] is fetching data from Microgrid database	Building Flexibility	?
6	[DSO LT module] is generating file from Building Flexibility table	Building Flexibility	?
7	[DSO staff] is preparing contract in "3Smart_LT module_v1.xlsm"		?
8	[DSO staff] is importing the prepared contract from "3Smart_LT module_v1.xlsm"	Import Contract	?

1. Initial screen – only download template is active
 - a. LT staff is downloading the template and enters input data in the excel

Operation of web based LT module

Long Term Workflow

Grid ▼

Building ▼

Contract ▼

Step	Activity	Link	Status
1	[DSO staff] is calculating flexibility needs, prices, penalty and quality of service by using "3Smart_LT module_v1.xlsm"	Template	✓
2	[DSO staff] is importing the results of "3Smart_LT module_v1.xlsm"	Import DSO Flex Table	?
3	[Building EMS Microgrid module] is fetching data from LT database		?
4	[Building EMS Microgrid module] is calculating flexibility offer		?
5	[DSO LT module] is fetching data from Microgrid database	Building Flexibility	?
6	[DSO LT module] is generating file from Building Flexibility table	Building Flexibility	?
7	[DSO staff] is preparing contract in "3Smart_LT module_v1.xlsm"		?
8	[DSO staff] is importing the prepared contract from "3Smart_LT module_v1.xlsm"	Import Contract	?

2. Building selected – import Dso Flex Table is also active

Operation of web based LT module

3Smart LT Home

Login

New contract created: Contract 2018 - G:1, B:1

DSO Flexibility table created

Flexibility unit prices and penalty imported

Import Excel

Grid

Grid 1

Building

A

Contract

New contract

Upload Excel

Tallózás...

- Overwrite existing contract data and clear corresponding Building Flexibility Table

Import Excel

3. Dso staff uploads the excel

Operation of web based LT module

3Smart LT Home

Login

Long Term Workflow

Grid

Building

Contract

Step	Activity	Link	Status
1	[DSO staff] is calculating flexibility needs, prices, penalty and quality of service by using "3Smart_LT module_v1.xlsx"	Template	✓
2	[DSO staff] is importing the results of "3Smart_LT module_v1.xlsx"	Import DSO Flex Table	✓
3	[Building EMS Microgrid module] is fetching data from LT database		?
4	[Building EMS Microgrid module] is calculating flexibility offer		?
5	[DSO LT module] is fetching data from Microgrid database	Building Flexibility	?
6	[DSO LT module] is generating file from Building Flexibility table	Building Flexibility	?
7	[DSO staff] is preparing contract in "3Smart_LT module_v1.xlsx"		?
8	[DSO staff] is importing the prepared contract from "3Smart_LT module_v1.xlsx"	Import Contract	?

4. Microgrid can take the data (Dso Flex table and Prices) and generate Building Flex Table for the given building

Operation of web based LT module

Long Term Workflow

Grid ▼

Building ▼

Contract ▼

Step	Activity	Link	Status
1	[DSO staff] is calculating flexibility needs, prices, penalty and quality of service by using "3Smart_LT module_v1.xlsm"	Template	✓
2	[DSO staff] is importing the results of "3Smart_LT module_v1.xlsm"	Import DSO Flex Table	✓
3	[Building EMS Microgrid module] is fetching data from LT database		✓
4	[Building EMS Microgrid module] is calculating flexibility offer		✓
5	[DSO LT module] is fetching data from Microgrid database	Building Flexibility	?
6	[DSO LT module] is generating file from Building Flexibility table	Building Flexibility	?
7	[DSO staff] is preparing contract in "3Smart_LT module_v1.xlsm"		?
8	[DSO staff] is importing the prepared contract from "3Smart_LT module_v1.xlsm"	Import Contract	?

5. When Microgrid's Building Flex is available the Building Flex Transfer button becomes active. At this stage we are using a dummy Microgrid Building Flex tablet to emulate that functionality until Microgrid is delivering.

Operation of web based LT module

Building Flexibility table imported

Long Term Workflow

Grid ▼

Building ▼

Contract ▼

Step	Activity	Link	Status
1	[DSO staff] is calculating flexibility needs, prices, penalty and quality of service by using "3Smart_LT module_v1.xlsm"	Template	✓
2	[DSO staff] is importing the results of "3Smart_LT module_v1.xlsm"	Import DSO Flex Table	✓
3	[Building EMS Microgrid module] is fetching data from LT database		✓
4	[Building EMS Microgrid module] is calculating flexibility offer		✓
5	[DSO LT module] is fetching data from Microgrid database	Building Flexibility	✓
6	[DSO LT module] is generating file from Building Flexibility table	Building Flexibility	?
7	[DSO staff] is preparing contract in "3Smart_LT module_v1.xlsm"		?
8	[DSO staff] is importing the prepared contract from "3Smart_LT module_v1.xlsm"	Import Contract	?

6. After transferring Building Flex, the corresponding download button and Import Contract becomes available

Operation of web based LT module

3Smart LT Home Login

Contract imported

Import Contract

Grid

Building

Contract

Upload Excel

7. The downloaded data (in excel file) goes into the original excel onto the Building Flexibility Table tab and excel is calculating the contract offer.

Operation of web based LT module

Long Term Workflow

Grid

Building

Contract

Step	Activity	Link	Status
1	[DSO staff] is calculating flexibility needs, prices, penalty and quality of service by using "3Smart_LT module_v1.xlsm"	Template	✓
2	[DSO staff] is importing the results of "3Smart_LT module_v1.xlsm"	Import DSO Flex Table	✓
3	[Building EMS Microgrid module] is fetching data from LT database		✓
4	[Building EMS Microgrid module] is calculating flexibility offer		✓
5	[DSO LT module] is fetching data from Microgrid database	Building Flexibility	✓
6	[DSO LT module] is generating file from Building Flexibility table	Building Flexibility	✓
7	[DSO staff] is preparing contract in "3Smart_LT module_v1.xlsm"		✓
8	[DSO staff] is importing the prepared contract from "3Smart_LT module_v1.xlsm"	Import Contract	✗

8. The entered Offer acceptance value will decide the final status of the contract

17)	Building offer accepted	yes/no	Manual entry
-----	-------------------------	--------	--------------

Operation of web based LT module

- The web based LT module will be available for all Members.
- It is database type independent.
- Local database was developed and connected web LT module also.
- The web based LT module is a type of workflow, the DSO user interaction is necessary because the process is semi-automated (see steps in operation pages).

https://10.133.128.11/3smart_lt/index

First time deployment- LT flexibility needs test

And other inputs, such as investment cost, penalty multiplier



A	B	C
Month	Type of day	Flexibility requirement [kW]
2019-01	WEEKDAYS	-71,94
2019-01	WEEKDAYS	-39,02
2019-03	WEEKDAYS	-66,13
2019-03	WEEKDAYS	-20,51
2019-04	WEEKDAYS	-62,86
2019-06	WEEKDAYS	-16,01
2019-06	WEEKDAYS	-51,02
2019-07	WEEKDAYS	-1,93
2019-10	WEEKDAYS	-59,98
2019-11	WEEKDAYS	-97,73
2019-11	WEEKDAYS	-47,66

Calendar Calculation input DSO Flexibilit



Caclulation of flexibility resource		
WACC	4,69%	
Inflation	2,50%	
The cost of investment	195 000	EUR
Ratio of used flexibility price	90%	
Year	2018	2019
WACC	4,7%	4,7%
Inflation	2,5%	2,5%
FV (Future Value)	195 000	200 302
Cost of Investment (with consideration of inflation)	195 000	199 875
Minimum amount of money available to cover the future investment	190 921	195 694
Maximum price of flexibility	4 079	4 608
Used price of flexibility (maximum*ratio)	3 671	4 147
Free amount of money after flexibility price	191 329	196 155
Unused source	408	461
Calculation of unit prices		
Reservation ratio	50,0%	
Penalty price multiplier	2	
Reservation part of Flexibility unit price	18,783	EUR/kW
Activation part of Flexibility unit price	0,061	EUR/kWh
Penalty	0,122	EUR/kWh
Quality threshold (max. devviation in size of service without penalty)	-10	%

First time deployment- LT flexibility needs test

Service name	Flexibility service		
1)	Contract valid from	dd.mm.yyyy.	
2)	Contract valid until	dd.mm.yyyy.	
3)	Est. no. of activations during period	238	Practically here will the number of activation be calculated within the contractual periode, i.e. the number of activations from Provided flexibility table by the Building
4)	Maximum Size of service in power (kW)	62,85980952	The algorithm seeks the maximum power within the Flexibility table provided by the Building (i.e. the maximum in the column "Provided flexibility by Building [kW]")
5)	Max. duration of service per activation (h)	5,00	The algorithm seeks the maximum duration within the Flexibility table provided by the Building (i.e. the maximum time interval)
6)	On - Trigger	Signal from the DSO or according to DA AC OPF calculator	Manual entry
7)	Off - Trigger	Maximum: see "Max.duration of service per activation" from "on"-signal, or by earlier signal from the DSO	From "Max.duration of service per activation(h)" and partly Manual entry
8)	Maximum allowed activation time	15 min (but it depends of the capability of the Customer process technology)	Manual entry
9)	Quality of Service	Deviation in max. duration: +/-	min Value
		Deviation from, On - Trigger: +/-	min Value
		Deviation in size of service: +/-	% of kW Value
		Acceptable no. of unsuccessful activations (above it terminate contract):	pcs Value
10)	Unit price of Reservation (EUR/kWh)	18,78287115	
11)	Unit price of Activation (EUR/kWh)	0,060837835	
12)	Reservation fee for the contractual period	1180,687703	
13)	Activation fee for the whole contractual period	981,7938414	
14)	Average activation price/activation	4,125184208	Since during the whole contractual periode the duration and size of activation varies day by day, therefore the whole amount of Activation fee ("Activation fee for the whole contractual period") will be divided by the number of activation from "Est. no. of activations during period"
15)	Pricing	2162,481544	Reservation fee for the whole contractual periode (in EUR)+ number of activation * Average activation price (in EUR)=EUR
16)	Penalty if failed supply	0,12167567	Calculation of penalty in case of failed delivery of one activation(zero activation): The fee of Sum of Activations* Percentage of the Activation fee for the whole contractual period.
		- Y times of failed delivery → termination of the contract	In case of partial service provision the slope of penalty curve can be found in "Input for longtermcontract_1" sheet of the Multiannual module
17)	Building offer accepted	yes/no	Manual entry

The contractual results which are based on calculations

Manual entry
Manual entry
Manual entry
Manual entry
Manual entry

3Smart modules organization on the EON pilot building

Árpád Rác

University of Debrecen

racz.arpad@science.unideb.hu

First pilot study visit to the Hungarian pilot

February 5-6, 2019.



Modules on the zone level

- Zone level prediction and estimation
 - Z.PE.1, Z.PE.8, Z.PE.9



Modules on the central HVAC system level

- Central HVAC system level prediction and estimation
 - HVAC.PE.1, HVAC.PE.2, HVAC.PE.4, M.PE.6
- Central HVAC system level model predictive control
 - HVAC.MPC.1 (heating), HVAC.MPC.2 (cooling)




Modules on the microgrid level

- Microgrid level prediction and estimation
 - M.PE.3, M.PE.4, M.PE.7, Z.PE.4, Z.PE.5, Z.PE.6
- Microgrid level model predictive control
 - M.MPC.1
- Microgrid level interfacing
 - M.I.4, M.I.5



Information flow between modules

E.ON building - Debrecen



3Smart First pilot study visit to the Hungarian pilot: On-line demonstrations: 3Smart modules installed on EON


Anita Martinčević, Nikola Hure, Danko Marušić, Hrvoje Novak

UNIZG FER

anita.martincevic@fer.hr, nikola.hure@fer.hr, danko.marusic@fer.hr, hrvoje.novak@fer.hr

3Smart pilot study visit to HUN pilot No. 1 in Debrecen

6 February 2019




Zone-level modules EON building

Z.PE.1 – offline

Fan coil unit identification submodule

Why is it needed?

Calculation of current thermal energy consumed by every fan coil unit equipped with return medium temperature sensors




Z.PE.1 – offline

Fan coil unit identification submodule

Main prerequisites:

1. Identification of temperature drop along the pipes
 - fan coil units grouped into 9 groups based on the length of supply pipeline



Z.PE.1 – offline

Fan coil unit identification submodule

Main prerequisites:










1. Identification of temperature drop along the pipes
 - fan coil units grouped into 9 groups based on the length of supply pipeline
 - for every group at least three manual measurements are performed by using the calibrated portable temperature sensor (UNIDEBTTK)
 - temperature drop function is identified by comparing those measurements with supply temperature measurements

Z.PE.1 – offline

Fan coil unit identification submodule

Main prerequisites:

1. Identification of temperature drop along the pipes




Z.PE.1 – offline

Fan coil unit identification submodule

Main prerequisites:

1. Identification of temperature drop along the pipes




Z.PE.1 – offline

Fan coil unit identification submodule

Main prerequisites:

1. Identification of temperature drop along the pipes
2. Calibration of return medium temperature sensors



Z.PE.1 – offline

Fan coil unit identification submodule

- **Hydraulic fan coil model** - based on experimental data recorded under special conditions



Z.PE.1 – offline

Fan coil unit identification submodule

- **Hydraulic fan coil model** - based on experimental data recorded under special conditions





- Experiments and data analysis done by UNIDEBTTK
- Data validated and entered to *fcu_hydraulic_model* table in database for E building

fcu_id	timestamp	flow_share
66	2018-10-19 10:49:07	NULL
67	2019-02-01 11:32:27	0.011
68	2019-02-01 11:32:27	0.0138
69	2019-02-01 11:32:27	0.009
70	2019-02-01 11:32:27	0.012
71	2019-02-01 11:32:27	0.013
72	2019-02-01 11:32:27	0.016
73	2019-02-01 11:32:27	0.0138
74	2019-02-01 11:32:27	0.0138
75	2019-02-01 11:32:27	0.0138
76	2019-02-01 11:32:28	0.00805
77	2019-02-01 11:32:28	0.0138
78	2019-02-01 11:32:28	0.0138
79	2019-02-01 11:32:28	0.0138

Z.PE.1 – offline

Fan coil unit identification submodule


- Identification of **thermodynamic fan coil model** based on experimental data (data recorded in special conditions)



Z.PE.1 – offline

Fan coil unit identification submodule

- Identification of **thermodynamic fan coil model** based on experimental data (data recorded in special conditions)




- Fan coil units operating in linear operation range
- Based on it we are able to estimate the fan state (low/medium/high)


Z.PE.1 – offline

Fan coil unit identification submodule

- Identification of **thermodynamic fan coil model** based on experimental data (data recorded in special conditions)




- Fan coil units operating in linear operation range
- Based on it we are able to estimate the fan state (low/medium/high)
- Identification of **electrical energy consumption model** of fan coil unit based on the manufacturer's catalogue data




Z.PE.1 – online Fan coil unit identification submodule

- Based on the identified **hydraulic, thermodynamic and electrical energy consumption** fan coil models and available measurements calculate the thermal and electrical consumption of every monitored fan coil unit



Z.PE.1 – online Fan coil unit identification submodule



Zone PE 4

Identification of the simplified building thermodynamic model

- Identification of continuous models performed for 6 zones with controllable electric heaters (UNIDEBTTK)
- Models are discretized with sampling times of 60 s and entered to database

zone_id	timestamp	continous_zone_model	discrete_zone_model_60
108	2018-10-01 12:06:27	{ "A": [[-9.0039e-04, 8.3663e-04], [1.3954e-0...	{ "A": [[0.9474, 0.0488], [8.1471e-04, 0.999...
109	2018-10-01 12:08:34	{ "A": [[-2.1580e-04, 1.9639e-04], [2.7782e-0...	{ "A": [[0.9871, 0.0117], [0.0017, 0.9983]], ...
110	2018-10-01 12:09:33	{ "A": [[-9.4844e-04, 9.1056e-04], [1.3169e-0...	{ "A": [[0.9447, 0.0531], [7.6781e-04, 0.999...
111	2018-10-01 12:10:11	{ "A": [[-3.5740e-04, 3.1408e-04], [5.0749e-0...	{ "A": [[0.9788, 0.0186], [3.0126e-07, 1.000...
112	2018-10-01 12:10:59	{ "A": [[-3.5915e-04, 3.2687e-04], [5.9492e-0...	{ "A": [[0.9787, 0.0194], [3.5307e-04, 0.999...
113	2018-10-01 12:11:42	{ "A": [[-8.4422e-04, 7.5321e-04], [5.3252e-0...	{ "A": [[0.9506, 0.0441], [3.1155e-06, 1.000...

Zone PE 5


Estimation of the states of the simplified building thermal dynamics model including also the estimation of heat disturbance in zone

- Waiting for `electric_heater` and `electric_heater_measurements` tables in database
- Containing information on
 - nominal powers of electric heaters
 - placement
 - current state (on/off)

Zone PE 9 – off-line initialization (prediction of zone heating/cooling energy consumption)

Historical weather measurements:

- Temperature
- Direct, diffuse solar irradiance




```

    # Terminal window showing command-line output for model initialization
    # The output lists various parameters and their values, such as:
    # Zone: 9
    # Model: ...
    # ...
    
```

Locally stored:
inputsXY_neuronsZ.net



MISSING



Historical zones temperature



MODULE INPUTS



HVAC-level modules UNIZGFER

HVAC PE 4 – non-controllable consumption

Consumed heat on the central calorimeter

-

(consumed heat in zones with fan coils measurements

+


calculated energy loss on the vertical supply lines)

HVAC PE 4 – calorimeter power calculation/measurement

$$P = \frac{q}{3.6} \cdot 4186 \cdot (T_{\text{supply}} - T_{\text{return}}) \quad [\text{W}]$$

- 3.6: m³/h to kg/s
- 4186: specific heat capacity of the medium

Calorimeter ID 1: A building




HVAC PE 4 – calorimeter power calculation/measurement

$$P = \frac{q}{3.6} \cdot 4186 \cdot (T_{\text{supply}} - T_{\text{return}}) \quad [\text{W}]$$

- 3.6: m³/h to kg/s
- 4186: specific heat capacity of the medium

Calorimeter ID 1: A building




HVAC PE 4 – calorimeter power calculation/measurement

$$P = \frac{q}{3.6} \cdot 4186 \cdot (T_{\text{supply}} - T_{\text{return}}) \quad [\text{W}]$$

- 3.6: m³/h to kg/s
- 4186: specific heat capacity of the medium

Calorimeter ID 4: E building




HVAC PE 4 – calorimeter power calculation/measurement

$$P = \frac{q}{3.6} \cdot 4186 \cdot (T_{\text{supply}} - T_{\text{return}}) \quad [\text{W}]$$

- 3.6: m³/h to kg/s
- 4186: specific heat capacity of the medium


Calorimeter ID 4: E building



HVAC MPC 1


Heating substation

3smart control




HVAC MPC 1 – module operation


- Description: medium temperature optimisation → costs and comfort
- Module interaction on HVAC level:
 - 4.2.1. - Microgrid MPC module
 - 4.3.1. – P&E modules
- Execution frequency: 15 minutes
- < 15 min. coordination between the microgrid and HVAC MPC



HVAC MPC 1 – information flow



HVAC MPC 1 – information flow



HVAC MPC 1 – information flow

MODULE INPUTS

4.3.1-P&E modules


Losses parameters, flow shares

$$(E_{t,nc})_N$$


4.4.1-P&E

Heat/cool. elements parameters

$$(E_{t,z})_N, (T_z)_N$$




Does flow change?



2019

HVAC MPC 1 – information flow



- Losses supply: flow shares & temperature drop (*partly defined, synthetic data*) --
hvac_pe2_fcu_outputs table


Model of pipework losses scale-up for entire building?

- Losses return: model parameters (*synthetic data*) –
hvac_pe2_calorimeter_return

Parameters: ----->
Signals: ----->

$$(x)_N = [x(0), x(1), \dots, x(N - 1)]$$

HVAC MPC 1 – information flow



- Non-controllable thermal loads: together with controllable loads form cumulative thermal energy consumption

$E_{t,nc}$ considered constant in predictions

Parameters:


Signals:

----->

—————>

$$(x)_N = [x(0), x(1), \dots, x(N - 1)]$$

HVAC MPC 1 – information flow




- Volatile el. prices obtained from MGRID module

ce considered constant
in predictions
0.12 [EUR/kWh]

- Heating energy price constant 0.08 [EUR/kWh] – possible volatility


Parameters:

Signals:



$$(x)_N = [x(0), x(1), \dots, x(N - 1)]$$

HVAC MPC 1 – information flow




- FCU parameters: table `fcu_thermodynamic_model` (*partly defined*)
- Zone energy demand/zone temperature predictions

Synthetic data

Parameters:

Signals:



$$(x)_N = [x(0), x(1), \dots, x(N - 1)]$$

HVAC MPC 1 scenario

- **B+C** and **E** EON buildings -- 2 supply temp. ref.
- **24h** ahead predictions
- approx. 2.5 min. optimisation duration
- problem is initialised with control values in medium range
- HVAC not operating from 20:00 to 6:30 next day


HVAC MPC 1 scenario – zone energy demands,



HVAC MPC 1 scenario – attainable zone energy




HVAC MPC 1 scenario – supply temperature ref.




hvac_mpc1_outputs.
supply_medium_temperature_reference

HVAC MPC 1 scenario – electrical energy cons.



HVAC MPC 1 scenario – optim. cost 24h ahead...



HVAC MPC 1 tables

hvac_mpc1_outputs
hvac_mpc1_outputs_history



HVAC.PE.1 and HVAC.PE.2

Vladimir Jovanović, Mirko Komatina, Nebojša Manić

UNIBGFME

vjovanovic@mas.bg.ac.rs

First pilot study visit - Debrecen

February 5-6, 2019



Project co-funded by European Union funds (ERDF, IPA)

HVAC.PE.1

- HVAC.PE.1 – Estimation of the offline module parameters
- Heat pump COP

HVAC.PE.1

HVACPE1_inputs_online	
FK. HeatPumpID	Int
Timestamp	DateTime
Heat pump ambient temperature	Real
Heat pump medium flow	Real
Heat pump ingoing medium temperature	Real
Heat pump outgoing medium temp.	Real


HVACPE1_outputs_offline	
FK. HeatPumpID	Int
PK. HeatPumpModelID	Int
Timestamp	DateTime
Heat pump COP parameter	Real

HVAC.PE.1

HVACPE1_outputs_online	
FK. HeatPumpID	Int
Timestamp	DateTime
Estimated el. energy cons. of the heat pump.	Real

HVAC.PE.1

HVACPE1_inputs_online	
FK. HeatPumpID	Int
Timestamp	DateTime
Heat pump ambient temperature	Real
Heat pump medium flow	Real
Heat pump ingoing medium temperature	Real
Heat pump outgoing medium temp.	Real



HVAC.PE.1



HVACPE1_outputs_offline	
FK. HeatPumpID	Int
PK. HeatPumpModelID	Int
Timestamp	DateTime
Heat pump COP parameter	Real

HVACPE1_outputs_online	
FK. HeatPumpID	Int
Timestamp	DateTime
Estimated el. energy cons. of the heat pump.	Real

HVAC.PE.1 – Results (Inputs tables)

- At the moment no results are available in the format of inputs tables.
- Calculations are made based on historical data supplied by EON.
- Module is developed and ready to be coded in Python for both off-line and on-line operation.

HVAC.PE.1 – Results (Outputs table)

- At the moment no results are available for the outputs tables.

HVAC.PE.2


- HVAC.PE.2 – Estimation of the offline module parameters

$$\Delta T = a + b \cdot T + c \cdot Q$$

- Coefficients (a, b and c)

HVAC.PE.2

HVACPE2_online_inputs	
FK. PipeworkID	Int
Timestamp	DateTime
Temperature of the medium coming out of the heat pump/heating substation	Real
Medium flow through the heat pump	Real



HVAC.PE.2



HVACPE2_calorimeter_supply_outputs_offline	
FK. PipeworkID	Int
FK. CalorimeterID	Int
PK. CalorimeterModelID Timestamp	Int
Parameters of the supply temp.	DateTime
model Flow share gain	varchar(250)
	Real

HVACPE2_calorimeter_supply_outputs_online	
FK. PipeworkID	Int
FK. CalorimeterID	Int
Timestamp	DateTime
Estimated (based on the model) supply temperature	Real
Estimated (based on the model) flow	Real

HVAC.PE.2

HVACPE2_online_inputs	
FK. PipeworkID	Int
Timestamp	DateTime
Temperature of the medium coming out of the heat pump/heating substation	Real
Medium flow through the heat pump	Real



HVAC.PE.2



HVACPE2_calorimeter_supply_outputs_offline	
FK. PipeworkID	Int
FK. CalorimeterID	Int
PK. CalorimeterModelID	Int
Timestamp	DateTime
Parameters of the supply temp.	varchar(250)
model Flow share gain	Real

HVACPE2_calorimeter_supply_outputs_online	
FK. PipeworkID	Int
FK. CalorimeterID	Int
Timestamp	DateTime
Estimated (based on the model) supply temperature	Real
Estimated (based on the model) flow	Real

HVAC.PE.2 – Results (Inputs tables)

- Measurement results from all calorimeters in EON building were provided yesterday.
- Calculations of coefficients a , b and c in the equation for temperature drop determination will be calculated ASAP.
- Afterwards, Python coding will be possible.

HVAC.PE.2 – Results (Outputs table)

3Smart First pilot study visit to the Hungarian pilot: On-line demonstrations: 3Smart modules installed on EON


Anita Martinčević, Nikola Hure, Danko Marušić, Hrvoje Novak

UNIZG FER

anita.martincevic@fer.hr, nikola.hure@fer.hr, danko.marusic@fer.hr, hrvoje.novak@fer.hr

3Smart pilot study visit to HUN pilot No. 1 in Debrecen

6 February 2019



Microgrid-level modules UNIZGFER

M PE 3 – off-line initialization

General prerequisites

1. Server connection (VPN SSTP)
2. Database connection (MySQL Workbench)
3. Python connection (PyCharm terminal, libraries etc.)
4. Virtualenv on the server side
5. Historical data analysis

M PE 3 – off-line initialization

General prerequisites

- 1. Server connection (VPN SSTP)**
2. Database connection (MySQL Workbench)
3. Python connection (PyCharm terminal, libraries etc.)
4. Virtualenv on the server side
5. Historical data analysis

M PE 3 – off-line initialization

General prerequisites

1. Server connection (VPN SSTP)
- 2. Database connection (MySQL Workbench)**
3. Python connection (PyCharm terminal, libraries etc.)
4. Virtualenv on the server side
5. Historical data analysis

M PE 3 – off-line initialization

General prerequisites

1. Server connection (VPN SSTP)
2. Database connection (MySQL Workbench)
- 3. Python connection (PyCharm terminal, libraries etc.)**
4. Virtualenv on the server side
5. Historical data analysis

M PE 3 – off-line initialization

General prerequisites


1. Server connection (VPN SSTP)
2. Database connection (MySQL Workbench)
3. Python connection (PyCharm terminal, libraries etc.)
- 4. Virtualenv on the server side**
5. Historical data analysis

M PE 3 – off-line initialization


General prerequisites

1. Server connection (VPN SSTP)
2. Database connection (MySQL Workbench)
3. Python connection (PyCharm terminal, libraries etc.)
4. Virtualenv on the server side
- 5. Historical data analysis**


M PE 3 – temperature measurements (initial)




M PE 3 – temperature measurements (filtered)




M PE 3 – temperature measurements (recent data)




M PE 3 – irradiance measurement (global)




M PE 3 – irradiance measurement (global)




M PE 3 – irradiance calculations (all data)




M PE 3 – irradiance calculations (recent)




M PE 3 –PV production measurements (initial)




M PE 3 –PV production measurements (after filtering)



M PE 3 –PV production measurements (recent data)




M PE 3 – on-line operation



M PE 3 – on-line operation

Regressor created from specific historical intervals of data:

- solar_zenith($t-1, \dots, t-3$)
- solar_azimuth($t-1, \dots, t-3$)
- temperature($t-1, \dots, t-3$)
- direct irradiance($t-1, \dots, t-3$)
- diffuse irradiance($t-1, \dots, t-3$)




M PE 3 – on-line operation


Regressor created from specific historical intervals of data:

- solar_zenith($t-1, \dots, t-3$)
- solar_azimuth($t-1, \dots, t-3$)
- temperature($t-1, \dots, t-3$)
- direct irradiance($t-1, \dots, t-3$)
- diffuse irradiance($t-1, \dots, t-3$)

Locally stored:
inputsXY_neuronsZ.net




M PE 3 – on-line operation




Regressor created from specific historical intervals of data:

- solar_zenith(t-1,...,t-3)
- solar_azimuth(t-1,...,t-3)
- temperature(t-1,...,t-3)
- direct irradiance(t-1,...,t-3)
- diffuse irradiance(t-1,...,t-3)

Locally stored:
inputsXY_neuronsZ.net




M PE 3 – on-line operation



Regressor created from specific historical intervals of data:

- solar_zenith(t-1,...,t-3)
- solar_azimuth(t-1,...,t-3)
- temperature(t-1,...,t-3)
- direct irradiance(t-1,...,t-3)
- diffuse irradiance(t-1,...,t-3)


Locally stored:
inputsXY_neuronsZ.net



Initial predictions: production spike around 1AM

Weather forecast error

M PE 3 – on-line operation



M PE 4 – non-controllable consumption

Overall electrical energy consumption of the building

-

electrical energy consumption of heat pumps (4 water chillers)

-

electrical energy consumption of electric heaters


+

electrical energy production of the PV system

-

El. energy consumption of fan coils (4 heating/cooling circuits)

M MPC 1




M MPC 1 – short-term

- The building provides the following services to the grid:
 - Prediction of day-ahead (DA) consumption
 - Following the declared DA consumption profile
 - Flexibility in consumption on grid's demand


- Control of electric heaters and PV plant

- Minimization of total building electricity cost:

$$J = J_{DA} + J_{BD} + J_{MP} + J_{IDf} + J_{flex,act,rew} + J_{flex,act,pen}$$



M MPC 1



Inputs

- Zone disturbance prediction
- Non-controllables prediction
- Estimated model of zones
- Parameters of electric heaters and PV plant
- Prices and requests from grid

Outputs

- Commands for electric heaters
- Commands for PV plant
- Energy profiles for the grid

M MPC 1 – data exchange – points for discussion

- storing electric heater and PV plant parameters?

mgrid_mpc1_inputs	
FK. microgrid_id	int
nctrl_elec_consumption_pred	varchar(2000)
nctrl_ther_consumption_pred	varchar(2000)
nctrl_gas_consumption_pred	varchar(2000)
pv_production_pred	varchar(2000)
batt_energy_exchange	varchar(2000)
batt_soc	real
batt_timestamp	datetime
rooms_temperatures	varchar(2000)
room_temperatures_timestamp	datetime
c_da	varchar(2000)
da_timestamp	datetime
c_pmax	real
c_pmax_timestamp	datetime
idf_penalty_factor	real
flex_reservation	varchar(2000)
flex_activation	varchar(2000)
flex_reservation_prices	varchar(2000)
flex_activation_prices	varchar(2000)
flex_penalty_prices	varchar(2000)
flex_penalty_threshold	real
lt_contract_timestamp	datetime


M MPC 1 – data exchange – points for discussion

- ctrl_load_command: JSON array of format
 {'room_id1':'energy',
 ...}
- pv_command: do we control the PV arrays separately?
- Measurement units?

mgrid_mpc1_outputs	
FK. microgrid_id	int
timestamp	datetime
batt_command	real
batt_energy_profile	varchar(2000)
ctrl_load_command	varchar(2000)
ctrl_load_energy_profile	varchar(4000)
pv_command	real
pv_energy_profile	varchar(2000)
coordination_var	varchar(16000)
predicted_da_profile	varchar(2000)


M MPC 1 – building-grid data exchange

- rule: have identical table structure as on the grid side




MPC coordination


- Can we obtain flexibility by adjusting HVAC consumption?
- Is that cheaper than using the battery?
- Iterative process
- Simulation environment:
 - UNIZGFER building
 - Heating season
 - Actual data for 2019-02-06
~09:00




MPC coordination – simulation environment



MPC coordination – results




Flexibility activation




Flexibility reservation



MPC coordination – results



DA profile following?




MPC coordination - results



- Thermal energy more expensive per kWh than electrical
- Decreased HVAC thermal consumption → increased HVAC electrical consumption
- Extra benefit: handling flexibility

MPC coordination - results



- Coordination: savings about 5% for given test case
- Two iterations enough

3Smart modules M.I.4-M.I.5-M.PE.7 on the EON pilot building

Árpád Rác

University of Debrecen

racz.arpad@science.unideb.hu

First pilot study visit to the Hungarian pilot

February 5-6, 2019.



e-on

M.I.4



Module information flow

MODULE INPUTS


Parameters of the heater
Room model
Energy command

MODULE

M.I.4

MODULE OUTPUTS

Switching signals for
each minute of the cycle



- EON building

Module operation


- Controllable load (room) has several power levels based on the number of heaters
 - Commanded energy is distributed equally during the next MPC cycle
 - Output power level is calculated for each minute
 - After each minute the energy consumption is measured
 - The output power levels the remaining minutes are recalculated
-
- **Frequency of module calls**
 - Every minute

M.I.5



Module information flow


MODULE INPUTS




MODULE



MODULE OUTPUTS



- EON building



Module operation

- Controllable load (room) has several power levels based on the number of heaters
 - Commanded energy is distributed equally during the next MPC cycle
 - Output power level is calculated for each minute
 - After each minute the energy consumption is measured
 - The output power levels the remaining minutes are recalculated
-
- **Frequency of module calls**
 - Every minute

On-line demonstrations – grid side

Gabor Hornyak

EON Tiszántúli Áramhálózati Zrt.

3Smart – Pilot study visit- Debrecen

06. – 05.02.2019.



UNIVERSITY OF ZAGREB
FACULTY OF
ELECTRICAL
ENGINEERING
AND COMPUTING



Interreg




EUROPEAN UNION

Danube Transnational Programme



3Smart

e-on

LONG TERM MODULES



Database: LT relevant tables on the server in Debrecen



The most important packages/technologies

```
from flask import Flask
from config import Config
from app.reverse_proxied import ReverseProxied

from flask_sqlalchemy import SQLAlchemy
from flask_bootstrap import Bootstrap
from flask_login import LoginManager
import os

excel_template_dir = os.path.join(os.path.dirname(os.path.realpath(__file__)), 'excel_template')
app = Flask(__name__)
# add config
app.config.from_object(Config)
# add bootstrap
bootstrap = Bootstrap(app)
# handling nginx location subfolders added to the URL during reverse proxying
app.wsgi_app = ReverseProxied(app.wsgi_app)

# database
db = SQLAlchemy(app)

# login
login = LoginManager(app)
login.login_view = 'login'

# routes is imported at last to avoid circular imports because routes is importing the app variable
from app import routes, models, errors
```

Creating default user at the first running

```
171
172 # user loader for login
173 @login.user_loader
174 def load_user(id):
175     return db.session.query(User).get(int(id))
176
177
178 # if user table empty then create an admin user
179 usr = db.session.query(User).first()
180 if usr is None:
181     usr = User()
182     usr.email = 'admin@3smart_lt.com'
183     usr.name = 'Default Admin'
184     usr.set_password('Default1234')
185     usr.active = True
186     usr.is_admin = True
187
188     db.session.add(usr)
189     db.session.commit()
190
```

Operation of web based LT module

Long Term Workflow

Grid

Building

Contract

Step	Activity	Link	Status
1	[DSO staff] is calculating flexibility needs, prices, penalty and quality of service by using "3Smart_LT module_v1.xlsm"	Template	?
2	[DSO staff] is importing the results of "3Smart_LT module_v1.xlsm"	Import DSO Flex Table	?
3	[Building EMS Microgrid module] is fetching data from LT database		?
4	[Building EMS Microgrid module] is calculating flexibility offer		?
5	[DSO LT module] is fetching data from Microgrid database	Building Flexibility	?
6	[DSO LT module] is generating file from Building Flexibility table	Building Flexibility	?
7	[DSO staff] is preparing contract in "3Smart_LT module_v1.xlsm"		?
8	[DSO staff] is importing the prepared contract from "3Smart_LT module_v1.xlsm"	Import Contract	?

1. Initial screen – only download template is active
 - a. LT staff is downloading the template and enters input data in the excel

Operation of web based LT module

Long Term Workflow

Grid

Building

Contract

Step	Activity	Link	Status
1	[DSO staff] is calculating flexibility needs, prices, penalty and quality of service by using "3Smart_LT module_v1.xlsm"	Template	✓
2	[DSO staff] is importing the results of "3Smart_LT module_v1.xlsm"	Import DSO Flex Table	?
3	[Building EMS Microgrid module] is fetching data from LT database		?
4	[Building EMS Microgrid module] is calculating flexibility offer		?
5	[DSO LT module] is fetching data from Microgrid database	Building Flexibility	?
6	[DSO LT module] is generating file from Building Flexibility table	Building Flexibility	?
7	[DSO staff] is preparing contract in "3Smart_LT module_v1.xlsm"		?
8	[DSO staff] is importing the prepared contract from "3Smart_LT module_v1.xlsm"	Import Contract	?

2. Building selected – import Dso Flex Table is also active

Operation of web based LT module

3Smart LT Home

Login

New contract created: Contract 2018 - G:1, B:1

DSO Flexibility table created

Flexibility unit prices and penalty imported

Import Excel

Grid

Grid 1

Building

A

Contract

New contract

Upload Excel

Tallózás...

- Overwrite existing contract data and clear corresponding Building Flexibility Table

Import Excel

3. Dso staff uploads the excel

Operation of web based LT module

3Smart LT Home

Login

Long Term Workflow

Grid

Building

Contract

Step	Activity	Link	Status
1	[DSO staff] is calculating flexibility needs, prices, penalty and quality of service by using "3Smart_LT module_v1.xlsx"	Template	✓
2	[DSO staff] is importing the results of "3Smart_LT module_v1.xlsx"	Import DSO Flex Table	✓
3	[Building EMS Microgrid module] is fetching data from LT database		?
4	[Building EMS Microgrid module] is calculating flexibility offer		?
5	[DSO LT module] is fetching data from Microgrid database	Building Flexibility	?
6	[DSO LT module] is generating file from Building Flexibility table	Building Flexibility	?
7	[DSO staff] is preparing contract in "3Smart_LT module_v1.xlsx"		?
8	[DSO staff] is importing the prepared contract from "3Smart_LT module_v1.xlsx"	Import Contract	?

4. Microgrid can take the data (Dso Flex table and Prices) and generate Building Flex Table for the given building

Operation of web based LT module

3Smart LT Home

Login

Long Term Workflow

Grid ▼

Building ▼

Contract ▼

Step	Activity	Link	Status
1	[DSO staff] is calculating flexibility needs, prices, penalty and quality of service by using "3Smart_LT module_v1.xlsm"	Template	✓
2	[DSO staff] is importing the results of "3Smart_LT module_v1.xlsm"	Import DSO Flex Table	✓
3	[Building EMS Microgrid module] is fetching data from LT database		✓
4	[Building EMS Microgrid module] is calculating flexibility offer		✓
5	[DSO LT module] is fetching data from Microgrid database	Building Flexibility	?
6	[DSO LT module] is generating file from Building Flexibility table	Building Flexibility	?
7	[DSO staff] is preparing contract in "3Smart_LT module_v1.xlsm"		?
8	[DSO staff] is importing the prepared contract from "3Smart_LT module_v1.xlsm"	Import Contract	?

5. When Microgrid's Building Flex is available the Building Flex Transfer button becomes active. At this stage we are using a dummy Microgrid Building Flex tablet to emulate that functionality until Microgrid is delivering.

Operation of web based LT module

3Smart LT Home

Login

Building Flexibility table imported

Long Term Workflow

Grid

Building

Contract

Step	Activity	Link	Status
1	[DSO staff] is calculating flexibility needs, prices, penalty and quality of service by using "3Smart_LT module_v1.xlsm"	Template	✓
2	[DSO staff] is importing the results of "3Smart_LT module_v1.xlsm"	Import DSO Flex Table	✓
3	[Building EMS Microgrid module] is fetching data from LT database		✓
4	[Building EMS Microgrid module] is calculating flexibility offer		✓
5	[DSO LT module] is fetching data from Microgrid database	Building Flexibility	✓
6	[DSO LT module] is generating file from Building Flexibility table	Building Flexibility	?
7	[DSO staff] is preparing contract in "3Smart_LT module_v1.xlsm"		?
8	[DSO staff] is importing the prepared contract from "3Smart_LT module_v1.xlsm"	Import Contract	?

6. After transferring Building Flex, the corresponding download button and Import Contract becomes available

Operation of web based LT module

3Smart LT Home Login

Contract imported

Import Contract

Grid

Building

Contract

Upload Excel

7. The downloaded data (in excel file) goes into the original excel onto the Building Flexibility Table tab and excel is calculating the contract offer.

Operation of web based LT module

Long Term Workflow

Grid

Building

Contract

Step	Activity	Link	Status
1	[DSO staff] is calculating flexibility needs, prices, penalty and quality of service by using "3Smart_LT module_v1.xlsm"	Template	✓
2	[DSO staff] is importing the results of "3Smart_LT module_v1.xlsm"	Import DSO Flex Table	✓
3	[Building EMS Microgrid module] is fetching data from LT database		✓
4	[Building EMS Microgrid module] is calculating flexibility offer		✓
5	[DSO LT module] is fetching data from Microgrid database	Building Flexibility	✓
6	[DSO LT module] is generating file from Building Flexibility table	Building Flexibility	✓
7	[DSO staff] is preparing contract in "3Smart_LT module_v1.xlsm"		✓
8	[DSO staff] is importing the prepared contract from "3Smart_LT module_v1.xlsm"	Import Contract	✗

8. The entered Offer acceptance value will decide the final status of the contract

17)	Building offer accepted	yes/no	Manual entry
-----	-------------------------	--------	--------------



Output Quality Report

Output title: T4.1 Transnational training activities	
Type of output:	<input checked="" type="checkbox"/> Documented learning interaction <input type="checkbox"/> Strategy/ Action Plan <input type="checkbox"/> Tool <input type="checkbox"/> Pilot action
Contribution to PO indicator:	P07 No. of documented learning interactions in finalised operations

<p>Summary of the output</p> <p>The output contains documented learning interactions performed during pilot study visits to the 3Smart locations for piloting of the developed modular tool for integrated grid-building energy management including demand response. Pilot study visits were attended by the members of the 3Smart consortium and for each pilot they were organized in two rounds. In the first round the pilot hosts explained the interventions performed while modules developers explained the needed steps for installation of the modules. In the second round the hosts explained the progress with modules installations while the developers presented the results of modules operation on data from the building.</p> <p>The documented learning interactions are organized as short explanation of how the learning interaction took place (minutes) which refer to presentation materials as annexes. For each round of pilot study visits a separate document is provided which contains the interactions from all five pilots of the 3Smart project –in Croatia, Slovenia, Austria, Bosnia and Herzegovina and Hungary. The reader can by passing through this documentation get a basic insight into the pilots organization and 3Smart platform operation on them.</p>

Added value

The output provides the information on pilots initial state, preparation actions for putting in place the 3Smart platform on the site, the architecture of the modular 3Smart system for a particular site i.e. which modules it contains to exhibit smart operation of the building or grid, needed steps for installation of modules as well as modules performance in operation.

The documentation provided was created by experts in particular fields to be understandable also to non-experts in that field. In this way, already within the consortium, which gathers versatile expertises, the information provided needed to be simple and easy to understand. The transnational context in which the materials arose ensures also its transnational relevance and can be used as a reference to interested stakeholders all across the Danube region and wider.

Applicability and replicability

The output can be used for a picturesque introduction to what was done on the project and to easily grasp the steps needed for replication of the 3Smart platform for energy management and demand response in a particular setup of a building or a grid. Different technologies in buildings were encompassed both on the level of zones (fan coils, radiators, floor heating/cooling), the central heating/cooling medium preparation (heat exchangers, heat pumps) and in shaping the overall energy flows between buildings and external grids (from nothing, which is also a viable option, to PV systems, batteries, CHPs, electric heaters, etc.). These varieties of implementation show the flexibility of the developed tool for adaptation at some new replication site, even in case it has some totally different configuration from any of the pilots.

Suggestions for improvement, if applicable

The output is useful to get an overview and impression how the 3Smart platform can be installed and what it can bring to a certain building or grid or even to a more complex setups. Especially useful are the estimations of gains which are also more concisely provided in other outputs, like Output T4.3 (presentations to stakeholders). This output can be considered as a useful interim material to get a gradual introduction into the 3Smart project developments. Considering the existence of more detailed written deliverables and outputs and that this is a material to get an overall impression on variety of implementation possibilities for 3Smart, I have no particular suggestions for improvement.

Output Quality Level

- Low
- Average
- Good
- Excellent

Name of the Quality Manager

Prof. dr. Mato Baotic

Signature of the Quality Manager

